

SENTRY MECHANICAL

1724 Leechburg Road
Pittsburgh, PA 15235
Phone: 412-795-3040
Fax: 412-795-3204
Service Fax: 412-795-3206

24 Hour Service



INVOICE NO
190236V

INVOICE

SOLD TO CMI Management, Inc
c/o Bernard Koblinsky
939 Freeport Road
Natrona Heights, PA 15065

SHIP TO pa017 clearfield boiler #2
6400 Clearfield Woodland Highw
Clearfield, PA 16830

ACCOUNT NO	PO NUMBER	SHIP VIA	JOB NUMBER	TERMS	INVOICE DATE	PAGE
CMIM001	CSS 15932		181903T	Net 30	3/14/2019	1

RE: CMI Management PA017 Clearfield - Boiler #2
CSS #15932
WO #5972
Asset #6599

Sentry Mechanical will provide and perform the following:

- replace burner kit
- replace ignitor kit
- replace ignitor cable replacement kit
- start up
- warranty

ITEM NO	QUANTITY	DESCRIPTION	UNIT PRICE	EXTENDED
LABOR	1:30	*Initial Call* HVAC Service Labor	98.00	147.00
LABOR	5.0	HVAC Service Labor	98.00	490.00
MATERIAL	1:00	Materials	677.19	677.19
MISC	1	Shipping	75.00	75.00

TOTAL AMOUNT 1,389.19

2/13/18



Management Inc.

The safety relief valve is not installed with the spindle in the vertical position. The safety or safety relief valve so the spindle is installed in the vertical position. The discharge pipe shall be equal to or exceed the total sectional area of the safety relief valve discharge(s). Piping shall be installed and supported so as not to induce a strain on the safety valve(s).

Burner is fluttering and locking out, ignitor and wire is worn, burner is internally fouled.

CERTIFICATION OF WORK
SERVICE CALL

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: PA017 Date of Visit: 1/15/19

Contractor Personnel on Site:

1. Dale Dohanich 4. _____
2. _____ 5. _____
3. _____ 6. _____

Service Call Number

CSS# 15932 WO# 5972

Description of Repairs

Boiler#2 - Replaced Ignition Tube, spark Ignitor, Spark wire & All Gaskets

Boiler#3 - Replaced Ignition Tube, Spark Ignitor, Spark wire & All gaskets

CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: Dale Dohanich Date: 1/15/19

Signed: Dale Dohanich


To be signed by Facility Manager:


By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: Leslie London GS09 Date: 1/15/19

Signed: Leslie London

E-Mail: _____





806181
106181
Pb



Q SERIES FINAL TEST

