

**CERTIFICATION OF WORK
PREVENTIVE MAINTENANCE**

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: NY039 Date of Visit: 8/24/22

Contractor Personnel on Site:

1. Patrick Brown 3. _____
2. _____ 4. _____

Work Performed:

Preventive Maintenance - Services Completed (Annual, Quarterly, Monthly, equipment identification, etc.)

1. WO#'S , 18321 , 18322 , 18489-18492 , 18550 , 18558 ,
2. 18559 , 18573 , 18574 , 18582 , 18593 , 18603 , 18604 ,
3. 18644 , 18493 , 18494 , 18560 , 18495 , 18496 , 18646
4. ASSET#'S , 9932 , 9935 , 9898 , 9929 , 9933 , 9934 , 9930 ,
5. 9940 , 9941 , 9946 , 9947 , IL-31 , IL-33 , 190917-, 253 , 254 ,
269 , 250 , 251 , 263 , 268 , 243 , 244 , 271 , 273

CERTIFICATION OF WORK

To be signed by the Contractor:


Print Name: Patrick Brown Date: 8/24/22

Signed: 

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: SSGT MIKE SHIFFLETT Date: 8/24/22

Signed: 

E-Mail: _____

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
INTERIOR LIGHTING

ACTIVITY AND BLDG #: **NY039 BLDG2&3**

MECHANIC
SIGNATURE: 

DATE: **8/24/22**

LOCATION/RM #: **BLDG2&3** WO# **18645**, ASSET # **IL-32**,
18646 **IL-33**

START TIME: **1:15pm**

FINISH TIME: **2pm**

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
TO BE PERFORMED AT EACH INSPECTION SERVICE				
1	Visually check all accessible areas for burned out bulbs and/or flickering lights. Check with the facility manager to see if they know of any outages.	✓		
2	Replace bulbs where applicable. Note quantity of bulbs replaced. If lift is required, schedule accordingly.	✓		
3	Test light fixture. If light does not work, replace starters and/or ballasts as necessary.	✓		
4	Note and report any needed electrical repairs.	✓		
5	Properly dispose of any non-working bulbs and ballasts.	✓		
6	Clean up area and remove any trash.	✓		

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: General Maintenance Worker

Additional Notes: