


PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST

INTERIOR LIGHTING

ACTIVITY AND BLDG #: NY039 BLDG3

MECHANIC
SIGNATURE: 

DATE: 3/2/23

LOCATION/RM #: BLDG3 WO# 20742 ASSET # IL-33

START TIME: 11:30am

FINISH TIME: 11:45am

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
TO BE PERFORMED AT EACH INSPECTION SERVICE				
1	Visually check all accessible areas for burned out bulbs and/or flickering lights. Check with the facility manager to see if they know of any outages.	✓		
2	Replace bulbs where applicable. Note quantity of bulbs replaced. If lift is required, schedule accordingly.	✓		
3	Test light fixture. If light does not work, replace starters and/or ballasts as necessary.	✓		
4	Note and report any needed electrical repairs.	✓		
5	Properly dispose of any non-working bulbs and ballasts.	✓		
6	Clean up area and remove any trash.	✓		

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed discription of the deficiency.

To be performed by: General Maintenance Worker

Additional Notes: