

**CERTIFICATION OF WORK
PREVENTIVE MAINTENANCE**

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: NY051 Date of Visit: 10 /5/22

Contractor Personnel on Site:

- | | |
|-------------------------|----------|
| 1. <u>Patrick Brown</u> | 3. _____ |
| 2. _____ | 4. _____ |

Work Performed:


Preventive Maintenance - Services Completed (Annual, Quarterly, Monthly, equipment identification, etc.)

- | | |
|----|--|
| 1. | WO#'S , 19235 , 19236 , 19288 , 19326 , 19338 , 19289 , 19339, 19290 |
| 2. | ASSET#'S , 10066 , 10069 , 190917-, 294 , 299 , 277 , 302 , IL-, 36,37 |
| 3. | _____ |
| 4. | _____ |
| 5. | _____ |

CERTIFICATION OF WORK

To be signed by the Contractor:


Print Name: PATRICK BROWN Date: 10/5/22

Signed: 

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: CPL TYLER ROSSO Date: 10/5/22

Signed: 

E-Mail: TYLER.J.ROSSO.MIL@ARMY.MIL

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST

INTERIOR LIGHTING

ACTIVITY AND BLDG #: NY051 BLDG1&2

MECHANIC
SIGNATURE: 

DATE: 10/5/22

LOCATION/RM #: BLDG1&2 WO# 19288, 19338, 19339, 19290 ASSET # IL-, 36,37, 190917-, 277,302

START TIME: 1pm

FINISH TIME: 2 pm

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
		TO BE PERFORMED AT EACH INSPECTION SERVICE		
1	Visually check all accessible areas for burned out bulbs and/or flickering lights. Check with the facility manager to see if they know of any outages.	✓		
2	Replace bulbs where applicable. Note quantity of bulbs replaced. If lift is required, schedule accordingly.	✓		
3	Test light fixture. If light does not work, replace starters and/or ballasts as necessary.	✓		
4	Note and report any needed electrical repairs.	✓		
5	Properly dispose of any non-working bulbs and ballasts.	✓		
6	Clean up area and remove any trash.	✓		

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed discription of the deficiency.

To be performed by: General Maintenance Worker

Additional Notes: