

**CERTIFICATION OF WORK
PREVENTIVE MAINTENANCE**

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: NY127 Date of Visit: 2/18/22

Contractor Personnel on Site:

- | | |
|-------------------------|----------|
| 1. <u>PATRICK BROWN</u> | 3. _____ |
| 2. _____ | 4. _____ |

Work Performed:

Preventive Maintenance - Services Completed (Annual, Quarterly, Monthly, equipment identification, etc.)

1. WO#'S , 15845 , 15868 , 15873 , 15852 , 15869 , 15874 ,
2. 15870 , 15875
3. ASSET#'S , 190917- , 646 , 648 , 649 , 653 , 654 , 656 , 657 ,
4. 661 , 684 , 602 , 621 , 644 , 724 , 712 , 687 , 729 , 732
5. _____

CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: Patrick Brown Date: 2/18/22

Signed: 

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: LARS LUFFMAN Date: 2/18/22


Signed: 

E-Mail: _____

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST

INTERIOR LIGHTING

ACTIVITY AND BLDG #: NY127 BLDG3

MECHANIC
SIGNATURE: 

DATE: 2/18/22

LOCATION/RM #: BLDG3 WO# 15870 ASSET # 190917-729

START TIME: 1:30pm

FINISH TIME: 1:45pm

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
TO BE PERFORMED AT EACH INSPECTION SERVICE				
1	Visually check all accessible areas for burned out bulbs and/or flickering lights. Check with the facility manager to see if they know of any outages.	☒	☒	no flickering lights
2	Replace bulbs where applicable. Note quantity of bulbs replaced. If lift is required, schedule accordingly.	☒	☒	no bulbs needed to be replaced
3	Test light fixture. If light does not work, replace starters and/or ballasts as necessary.	☒	☒	no starters or ballast replaced
4	Note and report any needed electrical repairs.	☒	☒	no needed electrical repairs
5	Properly dispose of any non-working bulbs and ballasts.	☒	☒	no bulbs replaced
6	Clean up area and remove any trash.	☒	☒	no trash

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: General Maintenance Worker

Additional Notes: