

**PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST**  
**INTERIOR LIGHTING**

ACTIVITY AND BLDG #: **NY127 BLDG1**MECHANIC  
SIGNATURE: DATE: **8/1/23**

LOCATION/RM #: **BLDG1** WO# **23173**, ASSET # **IL-65,**  
**23305** **190917-684**

START TIME: **7am**FINISH TIME: **7:30pm**

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
<b>TO BE PERFORMED AT EACH INSPECTION SERVICE</b>				
1	Visually check all accessible areas for burned out bulbs and/or flickering lights. Check with the facility manager to see if they know of any outages.	✓		
2	Replace bulbs where applicable. Note quantity of bulbs replaced. If lift is required, schedule accordingly.	✓		
3	Test light fixture. If light does not work, replace starters and/or ballasts as necessary.	✓		
4	Note and report any needed electrical repairs.	✓		
5	Properly dispose of any non-working bulbs and ballasts.	✓		
6	Clean up area and remove any trash.	✓		

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: General Maintenance Worker

**Additional Notes:**