



OneCIS Insurance Company

95 Oakwood Rd
Lake Zurich, IL 60047
(855) 593-5115
www.us.bureauveritas.com

BUREAU
VERITAS

8/8/2019

44110-007211.00

International Support Group
101 Lakeview Dr
Charleston, WV 25313-1467

RE: Jurisdictional Inspection:
International Support Group
101 Lakeview Dr
Charleston, WV 25313-1467

Thank you for the consideration I received during my visit on August 2, 2019 at your facility listed above. The purpose of the visit was to perform non- jurisdictional inspections of the objects listed below to determine compliance with ASME/National Board Inspection Code (NBIC) standards and regulations. I was accompanied by SSGT Salai during my visit.

The inspections were performed on behalf of International Support Group (US Army Reserve Offices).

The following objects were inspected while shut-down (not in operation) at the time of the visit:

Year Built	Type of object	Jurisdictional Number	NB Number	Recommendation(s)
2011	Water Tube	WV006BLR1	212639	None
2011	Water Tube	WV006BLR2	212640	None
2011	Water Tube	WV006BLR3	212641	None
2011	Water Tube	WV006BLR4	212642	None

The following observations were noted during the inspection of this equipment:

Each Boiler was inspected externally and found free of defect or damage. Required safety devices are installed and appear to be in good working order. Pressure relief devices were tested and found in satisfactory condition.

As a result of these inspections 0 new recommendations were suggested.

Based upon this visit and the results of the National Board Inspection Code (**NBIC**) inspection requirements, OneCIS Operating Certificates for each boiler are being created and forwarded to the client.

There were 2 noteworthy conditions reported that, although they fall outside of the **NBIC**, will require attention to assure boiler operability.

#1) It was reported that the control board, igniter and inducer draft assembly on the LAARS boiler #2 are in need of replacement.

#2) It was also reported that the igniters on the LAARS boilers #1, #3 and #4 need replaced.

The next inspections are tentatively scheduled to be completed by 08/2020.

Please contact me by phone at 571-373-0998 or by e-mail at william.johnson@onecis.com if there are any questions or if I may be of further assistance.

Sincerely,

William Garth Johnson

William Garth Johnson
B&M Jurisdictional Specialist

DISTRIBUTION

Cc:

International Support Group
Jamie Merchant
9050 Pines Blvd Ste 150
Pembroke Pines, FL 33024-6400
jmerchant@internationalsupportgroup.com