



OneCIS Insurance Company

95 Oakwood Rd
Lake Zurich, IL 60047
(855) 593-5115
www.us.bureauveritas.com



June 21, 2019

44110-007211.00

Abingdon Memorial USARC
571 Walden Rd
Abingdon, VA 24210-2207

HARD COPY

RE: Jurisdictional Inspection:
Abingdon Memorial USARC
571 Walden Rd
Abingdon, VA 24210-2207

Thank you for the consideration I received during my visit on May 17, 2019 at your facility listed above. The purpose of the visit was to perform the external inspections of the objects listed below to determine compliance with ASME/National Board rules and regulations. I was accompanied by Robert Demeo during my visit.

The inspections were performed on behalf of International Support Group (US Army Reserve Offices).

The following objects were inspected at the time of the visit:

Year Built	Type of object	Jurisdictional Number	NB Number	Recommendation(s)
2011	Cast Iron	VA001-BLR	CI	None

The following observations were noted during the inspection of this equipment:

Fittings, attachments, and accessible parts were closely examined and found in satisfactory condition. No adverse conditions were noted with respect to controls and safety valves.

As a result of this inspection, there were no recommendations suggested.

In order for the certificate(s) of operation to be renewed, all code violations must be cleared.

Based upon this visit, a report of this inspection activity is being forwarded to the governing jurisdiction. That report is requesting new certificates of operation be issued for the object with no adverse conditions noted.

The next inspection is tentatively scheduled to be completed by 05/17/2020.

Please contact me by phone at 571-373-0998 or by e-mail at william.johnson@onecis.com if there are any questions or if I may be of further assistance.

Sincerely,

William Garth Johnson

William Garth Johnson
B&M Jurisdictional Specialist

DISTRIBUTION

Cc:

Jamie Merchant, International Support Group
jmerchant@internationalsupportgroup.com

Thomas Kovach, OneCIS Insurance
Thomas.kovach@onecis.com

FILE