



## OneCIS Insurance Company

95 Oakwood Rd  
Lake Zurich, IL 60047  
(855) 593-5115  
[www.us.bureauveritas.com](http://www.us.bureauveritas.com)



June 21, 2019

44110-007211.00

Morgantown USARC  
228 Comfort Inn Rd  
Morgantown, WV 26508-3501

HARD COPY

**RE: Jurisdictional Inspection:**

Morgantown USARC  
228 Comfort Inn Rd  
Morgantown, WV 26508-3501

Thank you for the consideration I received during my visit on May 7, 2019 at your facility listed above. The purpose of the visit was to perform the external inspections of the objects listed below to determine compliance with ASME/National Board rules and regulations. I was accompanied by Jennifer Bailey during my visit.

The inspections were performed on behalf of International Support Group (US Army Reserve Offices).

The following objects were inspected at the time of the visit:

Year Built	Type of object	Jurisdictional Number	NB Number	Recommendation(s)
2011	Other	WV029-1	CP6119874	None
2011	Other	WV029-2	CP6119887	None
2011	Other	WV029-3	CP6119758	None
2011	Other	WV029-4	CP649755	None
2011	Other	WV029-5	CP611974	None

The following observations were noted during the inspection of this equipment:

***Fittings, attachments, and accessible parts were closely examined and found in satisfactory condition. No adverse conditions were noted with respect to controls and safety valves. While no safety issue is evident, WV029-5 is tagged out of service.***

As a result of this inspection, there were no safety recommendations suggested. However, I would be remiss if I did not pass on the information, related by several staff personnel, that these boilers are extremely difficult to keep running, apparently due to misapplied environmental/outside temperature

controls in the building. Technical manuals for these boilers emphasize the need for an alternative wiring scheme when outside temperature controls are in effect.

Based upon this visit, a report of this inspection activity is being forwarded to the governing jurisdiction. That report is requesting new certificates of operation be issued for the object with no adverse conditions noted.

The next inspection is tentatively scheduled to be completed by 05/15/2020.

Please contact me by phone at 571-373-0998 or by e-mail at [william.johnson@onecis.com](mailto:william.johnson@onecis.com) if there are any questions or if I may be of further assistance.

Sincerely,

*William Garth Johnson*

William Garth Johnson  
B&M Jurisdictional Specialist

DISTRIBUTION

Cc:

Jamie Merchant, International Support Group  
[jmerchant@internationalsupportgroup.com](mailto:jmerchant@internationalsupportgroup.com)

Thomas Kovach, OneCIS Insurance  
[Thomas.kovach@onecis.com](mailto:Thomas.kovach@onecis.com)

FILE