

EMTech dba / Energy Management Technologies, LLC  
 5 Hemlock Street  
 Latham, NY 12110  
 Phone # 518.783.7810

# Invoice

Date	Invoice #
1/31/2019	3407

## Bill To

CMI Management, Inc.  
 PM / 99th - Region 2  
 5285 Shawnee Road Suite #510  
 Alexandria, VA 22312

Project	P.O. No.	Terms		Due on receipt	
19801 Army Reserve T & M by location	Mike D. - Service Call	Due Date		1/31/2019	
Description		Qty	Rate	Serviced	Amount
Mike Duvall - Service Call Army Reserve Site: Schenectady HP 1-11 at Gym: Found small amount of oil at suction line access filling. Tightened valve and put a new cap on access port. Added 2 pounds of R410A HP 2-33: Found bad contactor compressor, control transformer blown fuse and fan wire off of fan relay. Found refrigeration circuit low on refrigerant. Added 2 pounds of R410A. Unable to access units very easily. Access covers 12" from wall. Mechanical service discounted local service contract rate. 410A Refrigerant Contract Discount Rate per pound 242 VAC Coil: 2 Pole Contactor Other Misc. supplies used for the service work performed on site.	8	108.00	1/8/2019		864.00T
	4	35.04			140.16T
	1	31.79			31.79T
		25.00			25.00T
<b>SALES TAX:</b> <i>If deducting sales tax from this invoice, please include your tax exempt certificate with payment.</i>		<b>Subtotal</b> \$1,060.95 <b>Sales Tax (8.0%)</b> \$84.88 <b>Total</b> \$1,145.83 <b>Payments / Credits</b> \$0.00 <b>Balance Due</b> \$1,145.83			
<b>For Assistance or Questions Please Contact</b> <b>Phone: (518) 783-7810 Extension 113</b> <b>Email <a href="mailto:cryan@emtechcontrols.com">cryan@emtechcontrols.com</a> Fax (518) 783-2079</b> <b>Thank you for your business!</b>					