

EMTech dba / Energy Management Technologies, LLC  
 5 Hemlock Street  
 Latham, NY 12110  
 Phone # 518.783.7810

# Invoice

Date	Invoice #
1/25/2019	3462

## Bill To

CMI Management, Inc.  
 PM / 99th - Region 2  
 5285 Shawnee Road Suite #510  
 Alexandria,VA 22312

Project	P.O. No.	Terms		Due on receipt	
19801 Army Reserve T & M by location	M. Duvall - Service Call	Due Date		1/25/2019	
Description		Qty	Rate	Serviced	Amount
Mike Duvall - Service Call for CMI Both boilers off on low water cut out. Condensate P-1 pulling 24 A Trip OL. Broke free impellar. P-1 not wat 4.2A P-2 at 4.1A. Filled boilers started up. Steam PSI at 5. Boilers good. Fixed 2 coils in building that had a leak in coil. Mechanical service discounted local service contract rate.		3.5	108.00	1/17/2019	378.00T
1 Trip - Mileage , Vehicle, Delivery, Charges		18	1.40		25.20T