

EMTech dba / Energy Management Technologies, LLC
 5 Hemlock Street
 Latham, NY 12110
 Phone # 518.783.7810

Invoice

Date	Invoice #
8/7/2019	4177

Bill To

CMI Management, Inc.
 PM / 99th - Region 2
 5285 Shawnee Road Suite #510
 Alexandria, VA 22312

Project	P.O. No.	Terms		Due on receipt	
19801 Army Reserve T & M by Location	CSS# 20398	Due Date		8/7/2019	
Description		Qty	Rate	Serviced	Amount
Saugerties Army Reserve - Service Call - CMI# 20398 Dave Ogden Found chiller pumps and AHU's 1&2 appear to be operating as designed. NAE Time was found to be 1.5 hours off - therefore the schedule would begin operating late. After being off for the weekend with unoccupied cooling (setpoint for 85 degrees) building felt warm. VAV133 is offline and should be checked. Mechanical HVAC discounted 5% southern county service contract labor rate.	2.5	118.00	7/22/2019		295.00T
1 Trip - Mileage, Vehicle, Delivery, Charges	110	1.40			154.00T
SALES TAX: <i>If deducting sales tax from this invoice, please include your tax exempt certificate with payment.</i>					
For Assistance or Questions Please Contact <i>Phone: (518) 783-7810 Extension 113</i> <i>Email cryan@emtechcontrols.com Fax (518) 783-2079</i>					
<i>Thank you for your business!</i>					
Subtotal \$449.00					
Sales Tax (8.0%) \$35.92					
Total \$484.92					
Payments / Credits \$0.00					
Balance Due \$484.92					