



# INVOICE

**Invoice Number:**  
16ST34954731

**Invoice Date:**  
07/25/2024

**Service Location:**  
New River Valley Memorial USARC  
(VA012)  
5746 Reserve Way  
Dublin, VA 24084

VSC Fire & Security, Inc.  
1201 Electric Road,  
Salem, VA 24153  
Phone: 540-765-1300  
Fax:

**Customer Number:**  
CUS007873

**Bill To:**  
CMI Management, LLC  
5285 Shawnee Road Suite #510  
Alexandria, VA 22312

Please remit payment to: VSC Fire & Security, Inc., PO Box 71207 Charlotte, NC 28272-1207 AR@vscfire.com

INVOICE DATE	CUSTOMER PO	PAYMENT TERMS	PROJECT ID
07/25/2024	CSS 97456	Net 30	16ST34954731

ITEM ID	DESCRIPTION	QTY	UNIT PRICE	EXT PRICE
STWI	EXT10732	10	74.00	740.00
STWI	EXT10215	1	74.35	74.35
STWI	12v 100ah battery	2	446.34	892.68
STWI	Notifier Photo Smoke Ivory	1	337.50	337.50
ST01AL	ST01-Service Tech	7	135.00	945.00

VA012 CSS 97456 WD 15419

**TERMS:** Net 30 days. Interest will be charged on past due accounts at the rate of 1.5% per month (annual interest rate - 18%) or the maximum permissible by law whichever is the lesser. We accept payment by VISA and MasterCard.

Sales Total	2,989.53
Tax Total	108.36
Net Amount	3,097.89

## Service Link

### New River Valley Memorial USARC (VA...

5746 Reserve Way  
Dublin, VA 24084

- [Summary](#)
- [Timeline](#)



## FIRE • SECURITY

### VSC Fire & Security, Inc.

**(540) 765-1300**

<https://vscfire.com>

1201 Electric Road  
Salem, VA 24153

SERVICE • TRADE  
Powered by

Job #34954731 - Repair

- Completed

VSC will replace (10) exit lights and (1) emergency light that failed to operate properly during the annual emergency light inspection. VSC will replace (1) smoke detector that was in trouble when the inspectors arrived to do the inspection on the fire alarm system and replace (2) 12v 100ah batteries that failed load testing during the annual fire alarm inspection.

It is the intention of VSC to provide documented and fully vaccinated employees to perform all onsite/jobsite work of the contract. However, VSC does not guarantee full compliance with all parts of Executive Order 14042.

#### Exclusions

1. ANY REPLACEMENT OF EXISTING DEFECTIVE MATERIALS OTHER THAN AS LISTED IN THE ABOVE SCOPE OF WORK.
2. UPGRADE TO THE EXISTING SYSTEM OR COMPONENTS.
3. ANY WEEKEND OR OVERTIME HOURS.
4. ANY DESIGN, DRAWINGS, PERMITS OR FEES.