



100 Snake Hill Road
West Nyack, NY 10994
(845) 358-1200
www.allbrightelectric.com

Invoice

No.

12952

Bill To: CMI MANAGEMENT
5282 SHAWNEE ROAD
SUITE 510
ALEXANDRIA, VA 22312

CS1007
Job: CSS#34448 FOR NY011 -BULLVILLE

Invoice Date	Customer No.	Payment Terms	Contract No.
2/14/2022	CMI001	Due Upon Receipt	
Quantity	Description	Rate/Unit	Price

4.00 1 MAN @ \$208.32 PER HOUR FOR (4) HOURS 208.32 833.28

2.00 FUSES 685.55 1,371.10

RESPONDED TO NO POWER AT BULLVILLE ARC OMS BUILDING.

FOUND (2) MV FUSES BLOWN IN THE MV SWITCHGEAR FOR THE OMS BUILDING.

A TREE LIMB WEIGHED DOWN BY ICE SHORTED TWO PHASES OF THE OVERHEAD MV FEED TO THE OMS BUILDING.

THE (2) FUSES WERE REPLACED, AND POWER WAS RESTORED TO THE OMS BUILDING.

THE ON SITE MAINTENANCE STAFF WAS ADVISED TO HAVE THE TREE REMOVED.

Gross	Retainage	Tax	Net Amount
2,204.38	0.00	111.40	2,315.78