

ATTACHMENT J-0200000-05
FORMS

CERTIFICATION OF WORK
(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: Pa 017

Date of Visit: 1/23/19

Contractor Personnel on Site:

1. <u>Tom Green</u>	4. _____
2. <u>Mark Sapienza</u>	5. _____
3. <u>Scott Werry</u>	6. _____

Work Performed:

Preventive Maintenance - Services Completed (Annual, Quarterly, Monthly, equipment identification, etc.)

1. <u>6954</u>	4. _____
2. <u>7038</u>	5. _____
3. _____	6. _____
4. _____	7. _____

CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: FRANCIS SAPIENZA Date: 1-23-19
Signed: Frank A. Sapienza

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: Tracy Huber Date: 23 Jan 19
Signed: Tracy Huber

E-Mail:

OTHER RECURRING SERVICES CERTIFICATION OF WORK
(To be completed by the Contractor and saved in the Contractor's CMMS)

FacID/Building: Pr 07 Date of Visit: 1/23/19

Contractor Personnel on Site:

1. Tony Lazarus
2. Scott Werry
3. Frank Sapienza

- 4.
- 5.
- 6.

Work Performed:

Other Recurring Services

1. 6925
- 2.
- 3.
- 4.

CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: FRANCIS SAPIENZA Date: 1-23-19
Signed: Frank Sapienza

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: Tracy Huber Date: 23 JAN 19
Signed: Z. Alta

E-Mail:

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
LIGHTING, OUTSIDESITE AND BLDG #: PA 017-01
LOCATION/RM #: PLG LOT WO# 6929 ASSET # 7468MECHANIC
SIGNATURE: Fahad Sul DATE: 1-2-19
START TIME: 6:34 PM FINISH TIME: 6:40 PM

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
SPECIAL INSTRUCTIONS				
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered to.	✓	✓	
2	Schedule and coordinate work with operating personnel.	✓		
3	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.		✓	
TO BE PERFORMED AT EACH INSPECTION SERVICE				
1	Open and tag switch.	✓		
2	Inspect visual condition of wiring. Look for evidence of overheating.	✓		
3	Check for proper light operation.	✓		
4	Test operation of automatic switches/ time clock/ photocells if applicable.	✓		
5	Inspect light pole and mounting devices for deficiencies.	✓		
6	For any noted deficiency, takes pictures and open corrective maintenance ticket.	✓		

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: General Maintenance Worker

Additional Notes:

6 PC FLOOD LITE, POLE MOUNT LED PHOTOCELL ON
FIXTURE
* 1 LITE OUT IN REAR LEFT CORNER OF VEHICLE LOT ^{ARMY}