

CERTIFICATION OF WORK
(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: PA 042

Date of Visit: 1/10/19

Contractor Personnel on Site:

1. Tony Gazzola
2. Jim Geertgens
3. Scott Werry
4. Frank Scienza
5. _____
6. _____

Work Performed:

Preventive Maintenance - Services Completed (Annual, Quarterly, Monthly, equipment identification, etc.)

1. 6914
2. 6988
3. 7066
4. _____

CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: Jim Geertgens Date: 1-10-19

Signed: Jim Geertgens

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: James T. Joseph SGT Date: 10 JAN 2019

Signed: James T. Joseph

E-Mail: james.t.joseph.3.mil@mail.mil

OTHER RECURRING SERVICES CERTIFICATION OF WORK
(To be completed by the Contractor and saved in the Contractor's CMMS)

FacID/Building: Pro92-01 Date of Visit: 1/10/19

Contractor Personnel on Site:

1. Tony Lazrus
2. Jim Geerligs
3. Scott Weir

4. FRANK S. Pierzz
5. _____
6. _____

Work Performed:

Other Recurring Services

1. 6914
2. _____
3. _____
4. _____

CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: Jim Geerligs Date: 1-10-19
Signed: Jim Geerligs

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: _____ Date: _____
Signed: _____

E-Mail: _____

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
GATES, FENCES, SECURITY AND ACCESS

SITE AND BLDG #:

Pr 002-0,

LOCATION/RM #:

MLP

WO# 6988

ASSET # 7521

MECHANIC
SIGNATURE:

START TIME:

1130

DATE: 1/10/13

FINISH TIME: 1140

ITEM NUMBER	DESCRIPTION	PROCEDURES	TO BE PERFORMED AT EACH INSPECTION SERVICE		NOTES
			LABOR COMBINED	MATERIALS	
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered.				
2	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.				
3	Inspect all pivot points, hinges, latches, etc. Apply lubricant where needed, wiping off excess.	/			
4	Check all locking devices. Lubricate as required.	/			
5	Clean roller track of any debris.	/			
6	Check bolts, fasteners, and mounting hardware. Tighten or adjust as necessary.	/			
7	Check for any obstructions that retard full swing or movement of the gate.	/			
8	Check that shrubs and trees are pruned clear of gate.	/			
9	Check hold open devices for proper operation. Lubricate as required.				
10	Check posts and corner posts, support guys, and horizontal bars between each support post.				
11	Check wire and anchor point; re-stretch and re-anchor if necessary.				
12	Inspect fence anchors along the bottom of the fence and at the point where the fence is connected to the post.				
13	Treat with galvanized protectant where rust has developed.				
14	If approved, apply weed control along entire base of fence. Consult the Safety Data Sheets (SDS) for hazardous ingredients and proper personal protective equipment (PPE).				
15	Check that shrubs and trees are pruned clear of fencing.				

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: General Maintenance Worker

Additional Notes:

C

PC

Double

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
GATES, FENCES, SECURITY AND ACCESS

SITE AND BLDG #:

Pp 042-01

LOCATION/RM #:

MEP

WO# 6988

ASSET # 7631

MECHANIC
SIGNATURE:

START TIME:

John

DATE:

1/10/19

FINISH TIME: 1150

ITEM NUMBER	DESCRIPTION/DEFICIENCIES	SKILL LEVEL	CODE PERFORMANCE REQUIREMENTS	INSPECTION SECTION	NOTES/COMMENTS	DATE PERFORMED	TECHNICIAN SIGNATURE
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered.						
2	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.						
1	Inspect all pivot points, hinges, latches, etc. Apply lubricant where needed, wiping off excess.						
2	Check all locking devices. Lubricate as required.						
3	Inspect center gate support rollers and lubricate as required.						
4	Clean roller track of any debris.						
5	Check bolts, fasteners, and mounting hardware. Tighten or adjust as necessary.						
6	Check for any obstructions that retard full swing or movement of the gate.						
7	Check that shrubs and trees are pruned clear of gate.						
8	Check hold open devices for proper operation. Lubricate as required.						
1	Check posts and corner posts, support guys, and horizontal bars between each support post.						
2	Check wire and anchor point; re-stretch and re-anchor if necessary.						
3	Inspect fence anchors along the bottom of the fence and at the point where the fence is connected to the post.						
4	Treat with galvanized protectant where rust has developed.						
5	If approved, apply weed control along entire base of fence. Consult the Safety Data Sheets (SDS) for hazardous ingredients and proper personal protective equipment (PPE).						
6	Check that shrubs and trees are pruned clear of fencing.						

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: General Maintenance Worker

Additional Notes:

1

Pp

Sagle

Swanson

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
MANUAL/AUTOMATIC ROLL-UP DOORS

ACTIVITY AND BLDG #: *Pr 042-01*LOCATION: *Drill well 6988 asset # 7681*MECHANIC
SIGNATURE: *[Signature]*DATE: *1/10/19*START TIME: *1100*FINISH TIME: *1115*

CHECKLIST ITEM	CHECKLIST DESCRIPTION	SPECIFIC INSTRUCTIONS	BEFORE/COMPLETELY		NOTES/EXCLUSIONS
			YES	NO	
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered.				
2	Review manufacturer's instructions.				
3	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.				
4	Check with door operating personnel for any known deficiencies.				
5	Inspect general arrangement of door and mechanism, mountings, standards, wind locks, anchor bolts, counterbalances, weather stripping, door sweeps etc. Clean, tighten, and adjust repair as required.				
6	If applicable, operate with power from start to stop and at intermediate positions. Observe performance of various components, such as brake, limit switches, door operating speed, motor, gear box, etc. Clean and adjust as needed.				
7	Check operation of safety edges, stops, electric eye, treadle, or other operating devices. Clean and make required adjustments or repairs.				
8	Check manual operation. Note brake release, motor disengagement, functioning of hand pulls, chains sprockets, clutch, etc.				
9	If applicable, examine all wiring, motor, starter, push button, etc., blow out or vacuum if needed.				
10	If applicable, inspect gear box, change or add oil as required.				
	Perform required lubrication. Remove old or excess lubricant.				
	Clean unit and mechanism thoroughly. Touch up paint where required.				
	Clean up and remove all debris.				

Note: The Contractor shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence.
 Checklist compiled in accordance with:

- Original equipment manufacturers (OEM) documentation for exact or similar assets, which can be located at [\(Provide Link to OEM Manual/Asset Library\)](#)
 Additional Notes:

l R 12x12

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
MANUAL/AUTOMATIC ROLL-UP DOORS

ACTIVITY AND BLDG #:

Pf 042-07

LOCATION: DPC

W# 6288 Ass# 1787

MECHANIC
SIGNATURE:

START TIME:

1115

DATE: 1/10/19

FINISH TIME: 1120

CHECKS PROC	CHECKPOINT DESCRIPTION	BLANK/COMPLETE		SPECIFIC INSTRUCTIONS	NOTES/ANCHORIS (IF HAVE COMPLETED OR REFERRED TO DOCUMENTATION)
		YES	NO		
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered.				
2	Review manufacturer's instructions.				
3	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.				
TO BE PERFORMED AT EACH INSPECTION SERVICE					
1	Check with door operating personnel for any known deficiencies.				
2	Inspect general arrangement of door and mechanism, mountings, standards, wind locks, anchor bolts, counterbalances, weather stripping, door sweeps etc. Clean, tighten, and adjust repair as required.				
3	If applicable, operate with power from start to stop and at intermediate positions. Observe performance of various components, such as brake, limit switches, door operating speed, motor, gear box, etc. Clean and adjust as needed.				
4	Check operation of safety edges, stops, electric eye, treadle, or other operating devices. Clean and make required adjustments or repairs.			NA	
5	Check manual operation. Note brake release, motor disengagement, functioning or hand pulls, chains sprockets, clutch, etc.			NA	
6	If applicable, examine all wiring, motor, starter, push button, etc., blow out or vacuum if needed.			NA	
7	If applicable, inspect gear box, change or add oil as required.				
8	Perform required lubrication. Remove old or excess lubricant.				
9	Clean unit and mechanism thoroughly. Touch up paint where required.				
10	Clean up and remove all debris.				

Note: The Contractor shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence.
 Checklist compiled in accordance with:

- Original equipment manufacturers (OEM) documentation for exact or similar assets, which can be located at ([Provide Link to OEM Manual/Asset Library](#))
 Additional Notes:

1 Pf 1115 1120