

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
LIGHTING, OUTSIDE

SITE AND BLDG #: NY058-104

MECHANIC : Mike Wolfe

10/11/19

SIGNATURE: *Mike Wolfe*

DATE:

START TIME: *18:30 am*

FINISH TIME: *1pm*

LOCATION/RM #:

Site Location	WO #	Asset #	PM #	Manufacturer	Model Number	Serial #	Asset Description	Asset Location
NY058-104	5628	10336	PM-MO-10336				J-45 10-pc Motor Vehicle Area Light Military Equipment Parking	

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)		
		YES	NO	SPECIAL INSTRUCTIONS		
TO BE PERFORMED AT EACH INSPECTION SERVICE						
1	Open and tag switch.			<i>AFTER CONSULTING WITH EXTERIAN MIKE SHEDO NO LIGHTS ARE</i>		
2	Inspect visual condition of wiring. Look for evidence of overheating.			<i>OPERATIONAL. CONNECTED TO AN ATOMICAL CLOCK THAT IS NOT OPERATIONAL</i>		
3	Check for proper light operation.					
4	Test operation of automatic switches/ time clock/ photocells if applicable.					
5	Inspect light pole and mounting devices for deficiencies.					
6	For any noted deficiency, takes pictures and open corrective maintenance ticket.					

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency. To be performed by: General Maintenance Worker **Additional Notes:**

*CM REQUESTED for Asset 10336
AUTOMATIC CLOCK NOT OPERABLE, RECOMMEND
REPAIR/REPLACEMENT*