

**Additional Funding Request
Corrective Maintenance from PM**

Submitted: 5/8/19

MD013 – Evaporator unit	CSS #18194 WO#8029 Asset# 2002
Description of Repairs	Condensing unit low on charge -ice build-up.
Diagnosis: Initial Work Order	<p>S&S proposes to furnish the labor and material necessary for the completion of the following:</p> <ul style="list-style-type: none"> - S&S will remove the old evaporator unit and replace with new evaporator unit. - Work will take place during normal business hours.
Explanation of Additional Costs for Repairs	N/A
Investigative Diagnosis fee from SC	\$550.00
Additional Material Cost to Perform Repairs	Material: \$423.90 Evaporator unit/FTK12NMVJU/=\$423.90
Additional Labor Cost to Perform Repairs	Labor: \$400.00 1 HVAC Technician /4 hours/ Rate \$100.00 per hour = \$400.00
Total of Corrective Maintenance Ticket	\$1,373.90
Minus \$250 – Cost of CM credit	(\$250.00)
Total Cost of Repair	\$1,123.90