

**CERTIFICATION OF WORK
PREVENTIVE MAINTENANCE**

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: MD002 Date of Visit: 02/22/22

Contractor Personnel on Site:

1. _____	3. _____
2. _____	4. _____

Work Performed:

Preventive Maintenance - Services Completed (Annual, Quarterly, Monthly, equipment identification, etc.)

1. _____
2. _____
3. _____
4. _____
5. _____

72

45

CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: Johnny W Brown Date: 02/22/22

Signed: 

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: SFC Cesar Torres Date: 02/22/22

Signed: 

E-Mail: _____

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
FILTER REPLACEMENT

SITE AND BLDG #: MD002 B-1

LOCATION/RM #: WO# 16246

MECHANIC
SIGNATURE:

DATE: 02/14/22

START TIME: 0900

FINISH TIME: 1630

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)		
		YES	NO			
TO BE PERFORMED AT EACH INSPECTION SERVICE						
1	Check, clean, and/or replace filters as required.	✓				
2	Initial and Date Filter (if disposable)	✓				
3	Initial and Date Yellow Maintenance Tag (if applicable)	✓				
ASSET #	SIZE	QTY	NOTES/ ACTIONS			
Record Size :						
1805	12x24x2 , 24x24x2	2&2				
1806	16x20x1, 20x20x1	6&12				
1807	24x24x2, 12x24x2	1&1				
1808	24x24x2	2				
NOTE : Any AHU with outside air -Filter gets replaced Quarterly						
All other filters get replaced annually But inspected Quarterly						

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: General Maintenance Technician

Additional Notes: