

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
LIGHTING, OUTSIDE

SITE AND BLDG #: MD002 B-6

MECHANIC
SIGNATURE: 

DATE: 08/16/22

190918-168

LOCATION/RM #: WO# 18848

ASSET #

START TIME: 0900

FINISH TIME: 1630

| CHECK POINT | CHECKPOINT DESCRIPTION | TASK COMPLETE | | NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION) |
|---|---|---------------|----|---|
| | | YES | NO | |
| SPECIAL INSTRUCTIONS | | | | |
| 1 | Schedule and coordinate work with operating personnel. | / | | |
| 2 | Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work. | / | | |
| TO BE PERFORMED AT EACH INSPECTION SERVICE | | | | |
| 1 | Inspect lighting contactor for pitting or arcing - report issues | / | | |
| 2 | Inspect visual condition of wiring. Look for evidence of overheating. | / | | |
| 3 | Check for proper light operation. | / | | |
| 4 | Test operation of automatic switches/ time clock/ photocells if applicable. | / | | |
| 5 | Inspect light pole and mounting devices for deficiencies. | / | | |
| 6 | For any noted deficiency, takes pictures and open corrective maintenance ticket. | / | | |

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: General Maintenance Worker

Additional Notes: