


PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
Sewage ejector ~~SUMP PUMP~~

SITE AND BLDG #: MD002 B-314

MECHANIC SIGNATURE:  **DATE:** 07/15/22

LOCATION/RM #: **WO#** 18395 **ASSET #** 1510

START TIME: 0900 **FINISH TIME:** 1630

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
SPECIAL INSTRUCTIONS				
1	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	/		
2	Excessive sediment and debris, not removed by flushing the pit should be handled on a project basis, and not considered under this standard.	/		
TO BE PERFORMED AT EACH INSPECTION SERVICE				
1	Remove cover plates and flush pit.	/		
2	Inspect check valve.	/		
3	Inspect interior of pit for cracks.	/		
4	Inspect cover plate is in place	/		
5	Insuure the unit is operating properly, report any deficiencies	/		
6	Clean up work area and remove all debris.	/		

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed discription of the deficiency.

To be performed by: General Maintenance Worker

Additional Notes: