

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST

CEILING MOUNTED HEAT PUMP

 MECHANIC
SIGNATURE:



DATE: 05/06/22

SITE AND BLDG #: MD002 B-2

LOCATION/RM #: WO# 17294 ASSET # MD02-101-211

START TIME: 0900

FINISH TIME: 1630

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
SPECIAL INSTRUCTIONS				
1	As needed, de-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work. Follow lock out/tag out procedures at all times.	✓		
TO BE PERFORMED AT EACH INSPECTION SERVICE				
1	Check fan blades for dust buildup and clean if necessary.	✓		
2	When applicable, check fan blades and moving parts for cracks and excessive wear.	✓		
3	Tighten all electrical connectors to proper torque asneeded.	✓		
4	Check contactors for compressors and fan.	✓		
5	Check dampers and rotating auto diffusers for dirt accumulations, clean as necessary. Check felt, repair or replace as necessary.	✓		
6	Lubricate mechanical connections of dampers sparingly as applicable.	✓		
7	Check the valve(s) for signs of leakage and proper operation. If leak is detected, submit a CM Request	✓		
8	Clean coils by brushing, blowing, vacuuming	✓		
9	Use fin comb to straighten coil fins as needed.	✓		
10	Check belts for wear and cracks, adjust tension or alignment as applicable. Replace belts when necessary.	✓		
11	Vacuum interior of unit.-Wipe down exterior of unit	✓		
12	Change the filter as needed with the correct size and type filter. Minimum annual Replacement.	✓		
13	Insure that drain(s) are clear and running.-Install condensate tablet	✓		
14	Clean up work area. - Record Humidity level in building	✓		Humidity _____ %
15	Sign and date yellow maintenance tag.	✓		

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed discription of the deficiency.

To be perfomed by: General Maintenance Worker

Additional Notes: