

**PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST**  
**DDC CONTROLLER**

SITE AND BLDG #: MD002 B-2

MECHANIC  
SIGNATURE:

DATE: 08/15/22

LOCATION/RM #: WO# 18842 ASSET # MD02-294 START TIME: 0900 FINISH TIME: 1630

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
<b>SPECIAL INSTRUCTIONS</b>				
1	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	/		
<b>TO BE PERFORMED AT EACH INSPECTION SERVICE</b>				
1	Obtain username and password for login. If not available, contact appropriate company manager to obtain access.	/		
2	Login into system, check for any alarms currently on system. Make necessary repairs to correct alarms back to normal state.	/		
3	Check physical condition of the device. Shut off power to the unit. Vacuum any remaining dust. Turn power back on to the unit.	/		
4	Check all fuses for evidence of heating or weakening.	/		
5	Check system for alarms	/		
6	Check all plug connections in the panel to ensure the plugs are fully seated.	/		

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: HVAC Technician

**Additional Notes:**