

Additional Funding Request

Submitted: 5/2/2019

MD021 – breaker for air compressor	CSS #18966 WO# 8835
Description of Repairs	Air compressor will not start after air is used, starter motor relay may need replaced, flipping breaker.
Original SC Investigative Diagnostic Total	\$400.00
Diagnosis: Initial Work Order	<p>S&S proposes to furnish the labor and material necessary for the completion of the following:</p> <ul style="list-style-type: none"> - S&S will remove the old breaker and replace with new 3 pole 80-amp breaker. - Work will take place during normal business hours.
Explanation of Additional Costs for Repairs	N/A
Additional Material Cost to Perform Repairs	<p>Material: \$168.00</p> <p>GE Breaker/THQB32080/\$150.00 Tax: \$18.00</p>
Additional Labor Cost to Perform Repairs	<p>Labor: \$150.00</p> <p>1 Electrician /1.5 hours/ Rate \$100.00 per hour = \$150.00</p>
Total Cost of Repair	\$718.00