

**CERTIFICATION OF WORK  
PREVENTIVE MAINTENANCE**

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: \_\_\_\_\_ Date of Visit: \_\_\_\_\_

Contractor Personnel on Site:

1. _____	3. _____
2. _____	4. _____

**Work Performed:**

**Preventive Maintenance** - Services Completed (Annual, Quarterly, Monthly, equipment identification, etc.)

1. \_\_\_\_\_
2. \_\_\_\_\_
3. \_\_\_\_\_
4. \_\_\_\_\_
5. \_\_\_\_\_

---

**CERTIFICATION OF WORK**

To be signed by the Contractor:


Print Name: \_\_\_\_\_ Date: \_\_\_\_\_

Signed: 

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: SSG Claudia Voorhies Date: \_\_\_\_\_

Signed: 

E-Mail: \_\_\_\_\_

Wednesday, November 6, 2019 11:15 AM EST

Tidewater, INC  
 MD-002  
 700 E. Ordnance Rd  
 Baltimore MD 21226  
 (410) 540-8700

Report Number: 275761  
 Recorded By: Paul Giammanco  
 (301) 721-2663  
 pgiammanco@bondwater.com  
 On-Site Time: 9:30 AM EST to 10:30 AM EST

## MD-002 - CLOSED LOOPS

Test	Chill Water Glycol Loop	Hot Water Loop		
Conductivity (as mmhos)	3200 3500 max	310 3500 max		
pH	9.5 8.5 - 10	8.5 8 - 10		
Molybdate (ppm as Mo)	0 80 min	0 80 min		

### Chill Water Glycol Loop

Online 

Performed Start up service visit. Performed all tests for chilled glycol loop. No treatment was detected, so I added 5011(molybdate) to the pot feeder until proper level was achieved.

### Hot Water Loop

Online 

Performed start up service visit. Performed all tests for hot water loop system. No treatment was detected in system, so I added 5011(molybdate) to pot feeder to achieve proper levels.