

Thursday, August 27, 2020 2:19 PM EDT

Tidewater, INC
 MD-002
 700 E. Ordnance Rd
 Baltimore MD 21226
 (410) 540-8700

Report Number: 339767
 Recorded By: Paul Giammanco
 (301) 721-2663
 pgiammanco@bondwater.com
 On-Site Time: 9:00 AM EDT to 10:00 AM EDT

MD-002 - CLOSED LOOPS

Test	Chill Water Glycol Loop	Hot Water Loop		
Conductivity (as mmhos)	4800 5000 max	4300 4500 max		
pH	9.8 8.5 - 10	9.6 8 - 10		
Molybdate (ppm as Mo)	100 50 min	200 50 min		

Opening Comment

Performed service visit.

Chill Water Glycol Loop

Online 

Performed all tests for chilled glycol system. All readings were within desired range, providing optimal corrosion protection.

Hot Water Loop

Online 

Hot water loop was not running during the time of visit, but I still ran testing regardless. All readings were within desired range, providing optimal corrosion protection.

Bond Water Technologies, Inc. recommends that you perform regular and/or daily analysis to control chemical levels and cycles of concentration within established limits. Test results reflect conditions during the point in time when the analysis was performed. Additional testing may be performed upon request. As operating conditions vary, test results will change over time. In no event shall Bond Water Technologies, Inc. be liable for any incidental, direct or indirect, consequential or special damages of any kind.

Bond Water Technologies, Inc. - 630 East Diamond Avenue, Suite J / K, Gaithersburg MD 20877 (301) 721-2663