

INSPECTION, TESTING, AND CERTIFICATION OF WORK
(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: MD002 Date of Visit: 3/27/18

Contractor Personnel on Site:

4. John Brown
5. Carl Deleaver
6. _____
4. _____
5. _____
6. _____

Work Performed:

Inspection, Testing, and Certification

5. Backflow Testing (QTY 6) (Annual) (QTY 4)
6. WO 2623 - Assets 1108 and 1109
7. WO 2624 - Assets 1117 and 1118
8. _____

CERTIFICATION OF WORK

To be signed by the Contractor: United Backflow

Print Name: Carl Deleaver Date: 3/27/18
Signed: Carlton E. Deleaver

To be signed by Facility Manager:

I certify that the above named individuals representing the Contractor arrived on site and to the best of my knowledge, completed the stated work listed:

Print Name/Rank: DINESH RUPCALL CIV Date: 03/27/2018
Signed: Dinesh Rupcall
E-Mail: DINESH.RUPCALL.CIV@NAZMIL



1-877-RPZ-TEST

Backflow Prevention Assembly Test Report

Property Name:	US Army Corps Reserve Bases
Street Address:	700 E. Ordinance Rd., Curtis Bay, MD, 21226
Onsite Contact:	
Onsite Phone:	
Contact Email:	
Assembly Status	<input type="radio"/> New Installation <input checked="" type="radio"/> Existing <input type="radio"/> Rebuilt <input type="radio"/> Replacement
Location:	Bldg 1
Service::	fire suppression system main line
Make::	Ames
Model:	2000SS
Serial Number:	1692690811
Size:	6"
Type::	DCVA
Asse #:	1015

INITIAL TEST: Pass Fail

INITIAL TEST DATE: **3/27/2018**

Shutoff #2 Close Tight: Y N

CV 1 Close Tight: Y N 4.4 PSID

CV 2 Close Tight: Y N 3.6 PSID

RPZ Relief Open: PSID

PVB Open: PSID

Line Pressure: 100 PSI

Air Gap OK: Y N

REPAIR FINAL TEST: Pass Fail

Final TEST DATE: _____

SHUTOFF #2 CLOSE TIGHT:

CHECK #1 CLOSE TIGHT: Y N

CHECK #2 CLOSE TIGHT: Y N

RPZ RELIEF OPEN PSID: _____

PVB OPEN PSID: _____

Comments

Tester License #: MD 12654

Gauge: Mid-West 845-5

Tester Name: Brian Douglass

Serial Number: 10172721

Signature: Brian Douglass

Last Calibration: 11/03/2017

MAIN CONTROL

Anytime Plumbing	
BLACKFISH INSPECTION	
INSPECTOR TAG	
CERTIFICATION OF	
BLACKFISH TEST	
Permit No.	1118
Sample Date	10/10/00
Water Meter	7000000000
Building Address	123 Main Street
Test Report No.	1234567890



1-877-RPZ-TEST

Backflow Prevention Assembly Test Report

Property Name:	US Army Corps Reserve Bases
Street Address:	700 E. Ordinance Rd., Curtis Bay, MD, 21226
Onsite Contact:	
Onsite Phone:	
Contact Email:	
Assembly Status	<input type="radio"/> New Installation <input checked="" type="radio"/> Existing <input type="radio"/> Rebuilt <input type="radio"/> Replacement
Location:	Bldg1
Service::	Domestic Supply
Make::	Wilkins
Model:	375
Serial Number:	L67999
Size:	4"
Type::	RPZA
Asse #:	1013

INITIAL TEST: Pass Fail

INITIAL TEST DATE: **3/27/2018**

Shutoff #2 Close Tight: Y N

CV 1 Close Tight: Y N 8.0 PSID

CV 2 Close Tight: Y N 4.2 PSID

RPZ Relief Open: 2.8 PSID

PVB Open: PSID

Line Pressure: 100 PSI

Air Gap OK: Y N

REPAIR FINAL TEST: Pass Fail

Final TEST DATE: _____

SHUTOFF #2 CLOSE TIGHT: _____

CHECK #1 CLOSE TIGHT: Y N

CHECK #2 CLOSE TIGHT: Y N

RPZ RELIEF OPEN PSID: _____

PVB OPEN PSID: _____

Comments _____

Tester License #: MD 12654

Gauge: Mid-West 845-5

Tester Name: Brian Douglass

Serial Number: 10172721

Signature: Brian Douglass

Last Calibration: 11/03/2017



Anytime Plumbing
BACKFLOW PREVENTION
INSPECTION TAG
CERTIFICATION OF
BACKFLOW TEST
Permit No. 332118
Date 7/26/18
Billing Address 700 E DELAWARE
Test Report No. 332118

2 1/2
INCHES
350PSI
WATER
VALVE