

INSPECTION, TESTING, AND CERTIFICATION OF WORK
(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: MD002 Date of Visit: 3/27/18

Contractor Personnel on Site:

4. <u>John Brown</u>	4. _____
5. <u>Carl Deleaver</u>	5. _____
6. _____	6. _____

Work Performed:

Inspection, Testing, and Certification

5. <u>Backflow Testing (QTY 6) (Annual) (QTY 4)</u>
6. <u>WO 2623 - Assets 1108 and 1109</u>
7. <u>WO 2624 - Assets 1117 and 1118</u>
8. _____

CERTIFICATION OF WORK

To be signed by the Contractor: United Backflow

Print Name: Carl Deleaver Date: 3/27/18
Signed: Carlton E. Deleaver

To be signed by Facility Manager:

I certify that the above named individuals representing the Contractor arrived on site and to the best of my knowledge, completed the stated work listed:

Print Name/Rank: DINESH RUPCALL CIV Date: 03/27/2018
Signed: Dinesh Rupcall
E-Mail: DINESH.RUPCALL.CIV@NAZMIL



1-877-RPZ-TEST

Backflow Prevention Assembly Test Report

Property Name:	US Army Corps Reserve Bases
Street Address:	700 E. Ordinance Rd., Curtis Bay, MD, 21226
Onsite Contact:	
Onsite Phone:	
Contact Email:	
Assembly Status	<input type="radio"/> New Installation <input checked="" type="radio"/> Existing <input type="radio"/> Rebuilt <input type="radio"/> Replacement
Location:	Bldg 2
Service::	Domestic
Make::	Wilkins
Model:	375 AST
Serial Number:	2010c
Size:	2-1/2"
Type::	RPZA
Asse #:	1013

INITIAL TEST: Pass Fail

INITIAL TEST DATE: **3/27/2018**

Shutoff #2 Close Tight: Y N

CV 1 Close Tight: Y N 8.8 PSID

CV 2 Close Tight: Y N 2.4 PSID

RPZ Relief Open: 2.0 PSID

PVB Open: PSID

Line Pressure: 120 PSI

Air Gap OK: Y N

REPAIR FINAL TEST: Pass Fail

Final TEST DATE: _____

SHUTOFF #2 CLOSE TIGHT: _____

CHECK #1 CLOSE TIGHT: Y N

CHECK #2 CLOSE TIGHT: Y N

RPZ RELIEF OPEN PSID: _____

PVB OPEN PSID: _____

Comments _____

Tester License #: MD 12654

Gauge: Mid-West 845-5

Tester Name: Brian Douglass

Serial Number: 10172721

Signature: Brian Douglass

Last Calibration: 11/03/2017

United Backflow
1-888-689-1662
www.unitedbackflow.com

THIS BACKFLOW ASSEMBLY

PASSED

IT'S MOST RECENT TEST
(SEE REVERSE)

SERIAL # 2010C
MAKE W.H.
MODEL 225AAT
SIZE 2 1/2"



1-877-RPZ-TEST

Backflow Prevention Assembly Test Report

Property Name:	US Army Corps Reserve Bases
Street Address:	700 E. Ordinance Rd., Curtis Bay, MD, 21226
Onsite Contact:	
Onsite Phone:	
Contact Email:	
Assembly Status	<input type="radio"/> New Installation <input checked="" type="radio"/> Existing <input type="radio"/> Rebuilt <input type="radio"/> Replacement
Location:	Bldg.2
Service::	fire suppression system main line
Make::	Ames
Model:	2000SS
Serial Number:	1678380411
Size:	6"
Type::	DCVA
Asse #:	1015

INITIAL TEST: Pass Fail

INITIAL TEST DATE: **3/27/2018**

Shutoff #2 Close Tight: Y N

CV 1 Close Tight: Y N 4.4 PSID

CV 2 Close Tight: Y N 4.4 PSID

RPZ Relief Open: PSID

PVB Open: PSID

Line Pressure: **110 PSI**

Air Gap OK: Y N

REPAIR FINAL TEST: Pass Fail

Final TEST DATE:

SHUTOFF #2 CLOSE TIGHT:

CHECK #1 CLOSE TIGHT: Y N

CHECK #2 CLOSE TIGHT: Y N

RPZ RELIEF OPEN PSID:

PVB OPEN PSID:

Comments

Tester License #: MD 12654

Gauge: Mid-West 845-5

Tester Name: Brian Douglass

Serial Number: 10172721

Signature: Brian Douglass

Last Calibration: 11/03/2017

United Backflow
1-888-689-1662
www.unitedbackflow.com

THIS BACKFLOW ASSEMBLY

PASSED

IT'S MOST RECENT TEST

(SEE REVERSE)

SERIAL # 1678380411

MAKE AMES

MODEL 200SC

SIZE 6"

PrintedTAGS.com