

**CERTIFICATION OF WORK
SERVICE CALL**

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: MD002

Date of Visit: 09/10/19

Contractor Personnel on Site:

Head Electrical
Mechanic →

1. Shawn Shipley

4. _____

Helper →

2. Malcolm Schlick

5. _____

3. _____

6. _____

Service Call Number

CSS# 13220

WO# ~~3754~~ 3781

Description of Repairs

Installed new operator, set limits and new
bottom weather strip + hose as well as pneumatic
boxes on ALL (3) Doors. Test operations by
running the doors multiple times + doors are
working good!

CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: Shawn Shipley Date: 09/10/19

Signed: Shawn Shipley

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: _____ Date: 9/19/19

Signed: Christopher Huebler

E-Mail: _____



OVERHEAD DOOR

RSX



WARNING
AVERTISSEMENT



VANGUARD POWER DOOR PRODUCTS, INC.
HAMARONECK, N.Y. 10540

UL LISTED
RESIDENTIAL DOOR OPERATOR FOR
COMMERCIAL AND INDUSTRIAL USE

WARNING: POWER
REVERSAL SYSTEM
REQUIRES CORRECT
INSTALLATION

WARNING: FOR PERMANENT CONNECTION TO HOUSE
WIRING, ALWAYS USE AN ADDED JUNCTION
BOX. INSTALLATION AND SERVICE REQUIREMENTS ARE
LISTED ON THE REVERSE OF THE COVER.

SEE INSTRUCTIONS FOR
WIRING AND SAFETY

CAUTION - SAFETY
SWITCH MUST BE CONNECTED.
SEE INSTALLATION INSTRUCTIONS.

