

Wednesday, February 9, 2022 10:36 AM EST

Tidewater, INC
MD-002
700 E. Ordnance Rd
Baltimore MD 21226
(410) 540-8700

Report Number: **442083**
Recorded By: **Bill Herring**
(443) 721-0698
bherring@bondwater.com

MD-002 - CLOSED LOOPS

Test	Chill Water Glycol Loop	Hot Water Loop		
Conductivity (as mmhos)	5200 5000 max	4725 Record		
pH	8.5 8.5 - 10	8.5 8 - 10		
Molybdate (ppm as Mo)	250 50 min	250 50 min		

Chill Water Glycol Loop

Online 

Performed all tests for chilled glycol loop. All readings indicate the system is holding plenty of inhibitor, providing optimal corrosion protection. Changed the filter on the system today.

Hot Water Loop

Online 

Performed all tests for hot water loop. All readings indicate the system is holding plenty of inhibitor, providing optimal corrosion protection. Changed the filter on the system today.

Bond Water Technologies, Inc. recommends that you perform regular and/or daily analysis to control chemical levels and cycles of concentration within established limits. Test results reflect conditions during the point in time when the analysis was performed. Additional testing may be performed upon request. As operating conditions vary, test results will change over time. Notwithstanding anything to the contrary contained in the Agreement or otherwise, (i) Bond Water Technologies and its Insurers are not liable for losses caused by the Customer's wrongful acts or omissions, (ii) Bond's program does not cover and it makes no guarantees with respect to waterborne pathogens including Legionella or against health risks therefrom, and (iii) in no event shall either party be liable for any consequential or indirect damages.