



1-844-RPZ-TEST

Backflow Prevention Assembly Test Report

Property Name:	US Army Corps Reserve Bases		
Property Address:	700 E. Ordinance Rd. Curtis Bay, MD. 21226		
Device Address:	700 E. Ordinance Rd.		
Onsite Contact:	Chris Huebler		
Onsite Phone:	443-614-7707		

Assembly Status:	☐ New Installation ☒ Existing ☐ Rebuilt ☐ Replacement		
Location:	Bldg 1		
Service:	Fire Protection		
Make:	Ames		
Model:	2000SS		
Serial Number:	1692690811		
Size:	6		
Type:	DCVA		

Test Date: 2/6/2020	Test Results: ☒ Pass ☐ Fail
---	---

Line Pressure: 65 Shutoff #2 Closed: ☒ Y ☐ N CV 1 Closed Tight: ☒ Y ☐ N 2.8 PSID CV 2 Close Tight: ☒ Y ☐ N 4.6 PSID RPZ Relief Open: ☐ Y ☐ N PSI PVB Open: ☐ Y ☐ N PSI Air Gap OK? ☐ Y ☐ N	Comments
---	---

Tester Name: Brian Douglass	Tester License #: MD 12654 WSSC 70369 VA 2717057302	Gauge Used: Mid-West 845-5 Serial Number: 10172721 Last Calibration: 10/29/2019
------------------------------------	--	--

United Backflow

1-888-689-1662

www.unitedbackflow.com

THIS BACKFLOW ASSEMBLY

PASSED

IT'S MOST RECENT TEST

(SEE REVERSE)

SERIAL # 169269089

MAKE AMEC

MODEL 2000LL

SIZE 6"

PRINTEDTAGS.COM



1-844-RPZ-TEST

Backflow Prevention Assembly Test Report

Property Name:	US Army Corps Reserve Bases		
Property Address:	700 E. Ordinance Rd. Curtis Bay, MD. 21226		
Device Address:	700 E. Ordinance Rd.		
Onsite Contact:	Chris Huebler		
Onsite Phone:	443-614-7707		

Assembly Status:	☐ New Installation ☒ Existing ☐ Rebuilt ☐ Replacement		
Location:	Bldg1		
Service:	Domestic Supply		
Make:	Wilkins		
Model:	375		
Serial Number:	L67999		
Size:	4"		
Type:	RPZA		

Test Date: 2/6/2020	Test Results: ☒ Pass ☐ Fail
----------------------------	---

Line Pressure: 65 Shutoff #2 Closed: ☒ Y ☐ N CV 1 Closed Tight: ☒ Y ☐ N 10 PSID CV 2 Close Tight: ☒ Y ☐ N 7.6 PSID RPZ Relief Open: ☒ Y ☐ N 2.0 PSI PVB Open: ☐ Y ☐ N PSI Air Gap OK? X Y ☐ N	Comments
---	---

Tester Name: Brian Douglass	Tester License #: MD 12654 WSSC 70369 VA 2717057302	Gauge Used: Mid-West 845-5 Serial Number: 10172721 Last Calibration: 10/29/2019
------------------------------------	--	--

United Backflow

1-888-689-1662

www.unitedbackflow.com

THIS BACKFLOW ASSEMBLY

PASSED

IT'S MOST RECENT TEST

(SEE REVERSE)

SERIAL #

L67999

MAKE

Wilkins

MODEL

325

SIZE

43

PrintedTAGS.com