



1-844-RPZ-TEST

Backflow Prevention Assembly Test Report

Property Name:	US Army Corps Reserve Bases		
Property Address:	700 E. Ordinance Rd. Curtis Bay, MD. 21226		
Device Address:	700 E. Ordinance Rd.		
Onsite Contact:	Chris Huebler		
Onsite Phone:	443-614-7707		

Assembly Status:	☐ New Installation ☒ Existing ☐ Rebuilt ☐ Replacement		
Location:	Bldg 2		
Service:	Domestic		
Make:	Wilkins		
Model:	375AST		
Serial Number:	2010c		
Size:	2-1/2"		
Type:	RPZA		

Test Date: 2/6/2020	Test Results: ☒ Pass ☐ Fail
----------------------------	---

Line Pressure: 65 Shutoff #2 Closed: ☒ Y ☐ N CV 1 Closed Tight: ☒ Y ☐ N 9.2 PSID CV 2 Close Tight: ☒ Y ☐ N 6.0 PSID RPZ Relief Open: ☒ Y ☐ N 2.0 PSI PVB Open: ☐ Y ☐ N PSI Air Gap OK? X Y ☐ N	Comments
--	---

Tester Name: Brian Douglass	Tester License #: MD 12654 WSSC 70369 VA 2717057302	Gauge Used: Mid-West 845-5 Serial Number: 10172721 Last Calibration: 10/29/2019
------------------------------------	--	--



1-844-RPZ-TEST

Backflow Prevention Assembly Test Report

Property Name:	US Army Corps Reserve Bases		
Property Address:	700 E. Ordinance Rd. Curtis Bay, MD. 21226		
Device Address:	700 E. Ordinance Rd.		
Onsite Contact:	Chris Huebler		
Onsite Phone:	443-614-7707		

Assembly Status:	☐ New Installation ☒ Existing ☐ Rebuilt ☐ Replacement		
Location:	Bldg.2		
Service:	Fire Protection		
Make:	Ames		
Model:	2000SS		
Serial Number:	1678380411		
Size:	6"		
Type:	DCVA		

Test Date: 2/6/2020	Test Results: ☒ Pass ☐ Fail
----------------------------	---

	Comments
Line Pressure: 65	
Shutoff #2 Closed: ☒ Y ☐ N	
CV 1 Closed Tight: ☒ Y ☐ N 2.8 PSID	
CV 2 Close Tight: ☒ Y ☐ N 5.0 PSID	
RPZ Relief Open: ☐ Y ☐ N PSI	
PVB Open: ☐ Y ☐ N PSI	
Air Gap OK? ☐ Y ☐ N	

Tester Name: Brian Douglass	Tester License #: MD 12654 WSSC 70369 VA 2717057302	Gauge Used: Mid-West 845-5 Serial Number: 10172721 Last Calibration: 10/29/2019
------------------------------------	--	--