

Friday, August 20, 2021 4:44 PM EDT

Tidewater, INC  
**MD-002**  
700 E. Ordnance Rd  
Baltimore MD 21226  
(410) 540-8700

Report Number: **371160**  
Recorded By: **Bill Herring**  
(443) 721-0698  
**bherring@bondwater.com**

## MD-002 - CLOSED LOOPS

Test	Chill Water Glycol Loop	Hot Water Loop		
Conductivity (as mmhos)	3445 5000 max	4095 Record		
pH	8.8 8.5 - 10	8.0 8 - 10		
Molybdate (ppm as Mo)	200 50 min	250 50 min		

### Opening Comment

SFC Jason Lamontagne gave excess into and from the boiler room.

#### Chill Water Glycol Loop

Online 

Performed all tests for chilled glycol loop. All readings were within desired range, providing optimal corrosion protection. A glycol sample was collected today and sent to the lab for testing.

#### Hot Water Loop

Online 

The tests readings indicate the the heat system is holding plenty of corrosion protection. The water has a lot of dark suspended solids and should be filtered or cleaned from the system.

Bond Water Technologies, Inc. recommends that you perform regular and/or daily analysis to control chemical levels and cycles of concentration within established limits. Test results reflect conditions during the point in time when the analysis was performed. Additional testing may be performed upon request. As operating conditions vary, test results will change over time. Notwithstanding anything to the contrary contained in the Agreement or otherwise, (i) Bond Water Technologies and its insurers are not liable for losses caused by the Customer's wrongful acts or omissions, (ii) Bond's program does not cover and it makes no guarantees with respect to waterborne pathogens including Legionella or against health risks therefrom, and (iii) in no event shall either party be liable for any consequential or indirect damages.