

### CERTIFICATION OF WORK

(To be completed by the Contractor and saved in the Contractor's CMMS)

### INSPECTION, TESTING, AND CERTIFICATION OF WORK

(To be completed by the Contractor and saved in the Contractor's CMMS)

Facility/Building: MD0002

Date of Visit: 7-5-19

Contractor Personnel on Site:

1. John Brown

2. Charles Brown

3. \_\_\_\_\_

4. \_\_\_\_\_

5. \_\_\_\_\_

6. \_\_\_\_\_

Work Performed:

#### Inspection, Testing, and Certification

1. Backflow Prevention Testing (Q3/4) (Annual) WO 7194 Asset 1108
2. WO 7194 Asset 1109 WO 7195 Asset 1117 WO 7196 Asset 1118
3. \_\_\_\_\_
4. \_\_\_\_\_

---

### CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: Charles R. Brown Date: 7-5-19

Signed: CRB

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline.

Print Name/Rank: John Leavitt SFC Date: \_\_\_\_\_

Signed: JL

E-Mail: JohnLeavitt14



1-877-RPZ-TEST

## Backflow Prevention Assembly Test Report

Property Name:	US Army Corps Reserve Bases
Street Address:	700 E. Ordinance Rd., Curtis Bay, MD, 21226
Onsite Contact:	
Onsite Phone:	
Contact Email:	
Assembly Status	<input type="radio"/> New Installation <input checked="" type="radio"/> Existing <input type="radio"/> Rebuilt <input type="radio"/> Replacement
Location:	Bldg 1
Service::	Fire Protection
Make::	Ames
Model:	2000SS
Serial Number:	1692690811
Size:	6"
Type::	DCVA
Asse #:	1015

### INITIAL TEST: Pass Fail

INITIAL TEST DATE: **2/5/2019**

Shutoff #2 Close Tight:  Y  N

CV 1 Close Tight:  Y  N 5.0 PSID

CV 2 Close Tight:  Y  N 3.0 PSID

RPZ Relief Open: **PSID**

PVB Open: **PSID**

Line Pressure: **100 PSI**

Air Gap OK:  Y  N

### REPAIR FINAL TEST: Pass Fail

Final TEST DATE:

SHUTOFF #2 CLOSE TIGHT:

CHECK #1 CLOSE TIGHT:  Y  N

CHECK #2 CLOSE TIGHT:  Y  N

RPZ RELIEF OPEN PSID:

PVB OPEN PSID:

Comments

Tester License #: MD 12654

Gauge: **Mid-West 845-5**

Tester Name: Brian Douglass

Serial Number: **10172721**

Signature: Brian Douglass

Last Calibration: **10/31/2018**



1-877-RPZ-TEST

## Backflow Prevention Assembly Test Report

Property Name:	US Army Corps Reserve Bases
Street Address:	700 E. Ordinance Rd., Curtis Bay, MD, 21226
Onsite Contact:	
Onsite Phone:	
Contact Email:	
Assembly Status	<input type="radio"/> New Installation <input checked="" type="radio"/> Existing <input type="radio"/> Rebuilt <input type="radio"/> Replacement
Location:	Bldg1
Service::	Domestic Supply
Make::	Wilkins
Model:	375
Serial Number:	L67999
Size:	4"
Type::	RPZA
Asse #:	1013

### INITIAL TEST: Pass Fail

INITIAL TEST DATE: **2/5/2019**

Shutoff #2 Close Tight:  Y  N

CV 1 Close Tight:  Y  N 8.2 PSID

CV 2 Close Tight:  Y  N 3.8 PSID

RPZ Relief Open: 2.0 PSID

PVB Open: PSID

Line Pressure: 100 PSI

Air Gap OK:  Y  N

### REPAIR FINAL TEST: Pass Fail

Final TEST DATE:

SHUTOFF #2 CLOSE TIGHT:

CHECK #1 CLOSE TIGHT:  Y  N

CHECK #2 CLOSE TIGHT:  Y  N

RPZ RELIEF OPEN PSID:

PVB OPEN PSID:

Comments

Tester License #: MD 12654

Gauge: Mid-West 845-5

Tester Name: Brian Douglass

Serial Number: 10172721

Signature: Brian Douglass

Last Calibration: 10/31/2018