

Additional Funding Request

Submitted 1.6.2020

MD013 Offices without heat	CSS #PENDING WO# 11474
Description of Repairs	Offices without heat. There are two heating line runs where the heat is not working. On the first floor the heat registers are cold to the touch, Rooms 118, 119, 120, 121, 123, 125 and 126. As the rest of the facility is working, suspect it is an issue in the line, not the boiler. Typical issues experienced are; air in the line or a stuck valve.
Diagnosis: Initial Work Order	There are two heating line runs where the heat is not working. On the first floor the heat registers are cold to the touch, Rooms 118, 119, 120, 121, 123, 125 and 126.
Diagnostic Fee:	\$400.00
Explanation of Additional Costs for Repairs	S & S proposes to furnish and install the following: S & S will remove and unclog all units not allowing water to pass. S & S will relocate the valve to allow air to reach the duct. S & S will then complete a system check to ensure everything is working properly.
Additional Labor Cost to Perform Repairs	HVAC tech / 18 hours labor / \$100.00 per hour rate = \$1,800.00
Additional Material Cost to Perform Repairs	Materials: \$88.36 6" Air Tite Collar / 14831 - 1.00 (quantity) - \$6.42 (Unit price) = \$6.42 Flex Duct/ 53343 - 1.00 (quantity) - \$44.40 (Unit price) = \$44.40 Tax = \$2.54 Shipping = \$35.00
Total Cost	\$2,288.36