

Additional Funding Request

Submitted: 1/24/2022

MD013-Return Valve Actuator	CSS # 34227 WO#16407											
Description of Repairs	S&S proposes to remove and replace the return valve actuator. S&S will then complete a system check to ensure everything is running properly.											
Original SC Investigative Diagnosis	\$200.00											
Diagnosis: Initial Work Order	No heat in G1 area, rooms 123-126 57f in classroom also											
Explanation of Additional Costs for Repairs	N/A											
Additional Material Cost to Perform Repairs	Materials:\$589.27 <table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th style="text-align: left; padding: 2px;">ITEM</th> <th style="text-align: left; padding: 2px;">QUANTITY</th> <th style="text-align: left; padding: 2px;">UNIT PRICE</th> <th style="text-align: left; padding: 2px;">TOTAL</th> </tr> </thead> <tbody> <tr> <td style="text-align: left; padding: 2px;">Spring Return Actuator/Shipping</td> <td style="text-align: left; padding: 2px;">589.27</td> <td style="text-align: left; padding: 2px;">\$589.27</td> <td style="text-align: left; padding: 2px;">\$589.27</td> </tr> </tbody> </table>				ITEM	QUANTITY	UNIT PRICE	TOTAL	Spring Return Actuator/Shipping	589.27	\$589.27	\$589.27
ITEM	QUANTITY	UNIT PRICE	TOTAL									
Spring Return Actuator/Shipping	589.27	\$589.27	\$589.27									
Additional Labor Cost to Perform Repairs	Labor: \$600.00 6 hours each/HVAC Rate \$100.00 per hour = \$600.00											
Total Cost of Repair	\$1,389.27											