

CERTIFICATION OF WORK

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: Gaithersburg MD013 Date of Visit: 5/20/19

Contractor Personnel on Site:

1. Patrick Donovan 2. _____

Work Performed:

Preventive Maintenance - Services Completed (Annual, Quarterly, Monthly, equipment identification, etc.)

1. 8485, 8515, 8546, 8516, 8547, _____

Service Calls – Service Call Number and Description

1. CSS# _____
2. CSS# _____
3. CSS# _____

CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: Patrick Donovan Date: 5/20/19

Signed: Patrick Donovan

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: ARF: S/MAULANI L. GENE Date: 5/20/19

Signed: Gene

E-Mail: gene.maulani@usgs.gov

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
AIR COOLED CHILLER, PACKAGE UNIT

MECHANIC SIGNATURE:  DATE: 6/4/19

SITE AND BLDG #: Gaithersburg MD 20878
LOCATION/RM #: 8515 WO# 8515 ASSET # 1989

START TIME: 12:30 FINISH TIME: 1:30

ITEM	DESCRIPTION	NOTES
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered to.	<input checked="" type="checkbox"/>
2	Follow lock out-tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	<input checked="" type="checkbox"/>
3	Comply with the latest provisions of the Clean Air Act and Environmental Protection Agency (EPA) regulations as they apply to protection of stratospheric ozone.	<input checked="" type="checkbox"/>
4	No intentional venting of refrigerants is permitted. During the servicing, maintenance, and repair of refrigeration equipment, the refrigerant must be recovered.	<input checked="" type="checkbox"/>
5	Whenever refrigerant is added or removed from equipment, record the quantities on the appropriate forms. Forms to be maintained by technician in universal waste binder.	<input checked="" type="checkbox"/>
6	Recover, recycle, or reclaim the refrigerant as appropriate.	<input checked="" type="checkbox"/>
7	If disposal of the equipment item is required, follow regulations concerning removal of refrigerants and disposal of the item.	<input checked="" type="checkbox"/>
8	If materials containing refrigerants are discarded, comply with EPA regulations as applicable.	<input checked="" type="checkbox"/>
9	Refrigerant oils to be treated as hazardous waste.	<input checked="" type="checkbox"/>
10	Closely follow all safety procedures described in the Safety Data Sheet (SDS) for the refrigerant and all labels on refrigerant containers.	<input checked="" type="checkbox"/>
11	Remove access covers prior to accomplishing check points.	<input checked="" type="checkbox"/>
1	Remove debris from air screen and clean underneath unit	<input checked="" type="checkbox"/> <i>done</i>
2	Pressure wash coil with proper cleaning solution	<input checked="" type="checkbox"/> <i>done</i>
3	Straighten fin tubes with fin comb	<input checked="" type="checkbox"/>
4	Check electrical wiring and tighten loose connections. Check fused disconnect switches for condition and operation	<input checked="" type="checkbox"/>

5	Check mounting for tightness	✓	done
6	Check for corrosion. Clean and treat with inhibitor as needed	✓	done good
7	Check fan or blower for bent or damaged blades and imbalance	✓	done good
8	1 Lubricate shaft and motor bearings on fans and remove old or excess lubricant, if applicable	✓	done good
9	Inspect pulleys, belts, couplings, etc., adjust tension and tighten mountings as necessary. Change badly worn belts. Multi-belt drives should be replaced with matched sets.	✓	all good
1	Inspect evaporator for any obvious deficiencies	✓	
2	Inspect plumbing, valves and flanges for leaks and correct as needed	✓	done
3		✓	
4	1 Lubricate drive coupling, if applicable	✓	done
5	2 Lubricate motor bearings (non-thermene), if applicable	✓	done
6	3 Check bearings for vibrations or unusual noises	✓	done
7	4 Leak test unit with soap test or electronic device	✓	done
8	5 Check compressor oil level, if applicable	✓	done
9	6 Run machine, check action of controls, relays, switches, etc. to see that a Compressor(s) run at proper settings	✓	all good
10	7 a) Suction and discharge pressures are proper	✓	done
11	8 Check vibration eliminators. Replace as necessary	✓	done
12	9 Check safety controls for high pressure cut off	✓	
13	10 Check for any other deficiencies	✓	
14	11 Confirm chiller is operating through building automation	✓	Supply Air 57.1
Note: The technician shall perform any repairs identified during PMI up to \$250 (direct labor and direct material cost per PMI occurrence) for any deficiencies found exceeding \$250 open a corrective maintenance (CMII) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency to be performed by HVAC technician			
Additional Notes:			

Compressor Amp Draw

Condenser Motor Amp Draw

Chilled water temp

#1 6.3 Cphase Bphase 4.9 Aphase S.
 #2 8.7 Aphase 7.0 Bphase Cphase 6.1
 #1Amp. 2 B) 20.1 C) 28.1
 #2 33.8Aphase Cphase 36.3 B phase 39.7

Comp #2 Low side 60
 High side 265