

CERTIFICATION OF WORK

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: Gaithersburg MD-013 Date of Visit: 6/5/19

Contractor Personnel on Site:

1. Patrick Donoran 2. _____

Work Performed:

Preventive Maintenance - Services Completed (Annual, Quarterly, Monthly, equipment identification, etc.)

1. 8855, 8885, 8931, 8856, 8932, 8887

Service Calls – Service Call Number and Description

1. CSS# _____
2. CSS# _____
3. CSS# _____

CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: Patrick Donoran Date: 6/5/19

Signed: [Signature]

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: Tara St-Laurent GS-11 Date: 05 Jun 19

Signed: [Signature]

E-Mail: Tara.F.StLaurent.civ@mail.mil

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST VEHICLE EXHAUST REMOVAL

SITE AND BLDG #:

Gaithersburg

MD013

LOCATION/RM #:

Bldg # 2

WO# 8932

ASSET # 1530

MECHANIC
SIGNATURE:


DATE:

6/5/19

START TIME:

8:45

FINISH TIME:

9:10

1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered.	<input checked="" type="checkbox"/>			
2	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	<input checked="" type="checkbox"/>			
1	Start and stop fan with local switch	<input checked="" type="checkbox"/>			done
2	Check motor and fan shaft bearings for noise, vibration, overheating; lubricate bearings.	<input checked="" type="checkbox"/>			all good
3	Inspect, adjust belts and pulleys. Replace belt as needed.	<input checked="" type="checkbox"/>			upok
4	Clean dampers; lubricate pivot points (annually) and inspect linkages for tightness.	<input checked="" type="checkbox"/>			done
5	Inspect fan for bent blades, imbalance, excessive noise and vibration.	<input checked="" type="checkbox"/>			done
6	Clean fan as needed.	<input checked="" type="checkbox"/>			all good
7	Visually inspect exhaust system tubing and/or duct work for any damage that could result in leaks.	<input checked="" type="checkbox"/>			all good
8	Repair as needed	<input checked="" type="checkbox"/>			all good

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: General Maintenance Worker

Additional Notes: