

Tina Lee

From: Richard Hicks
Sent: Monday, June 28, 2021 9:53 AM
To: Kenneth P CIV USARMY 99 RD (USA) Augustin; Rigney, Nathan Lynn CTR (USA); Tina Lee
Cc: Devlin, Thomas J CIV USARMY CENAP (USA)
Subject: MD013 Building Automation WO# 14180 CSS# 30530

Ken per our conversation on Thursday –

- Maximo notes : 6/14-investigated -proposal coming 6/28 - The Trane unit is fully operational - There is an alarm on building automation due to a failed component-Rick spoke to Ken about addressing this through the building automation group within the 99th . -VS- going to Tustin group for repairs --6/28-closing with S&S diagnostic costs

Work Order	Description	Site
14180	Check out the building Automation not Communicating with Trane Unit	99REG5

Thanks
Rick

Rick Hicks
Project Manager Region 5
CMI Management Inc.
5285 Shawnee Road Suite #510
Alexandria,VA 22312
703-738-5301
Richard.Hicks@cmimgmt.com