

CMI Management
 MD 013
 8791 Snouffers School Rd
 Gaithersburg MD 20879
 (202) 437-5119

Report Number: 458002

Recorded By: James Harris
 (410) 991-7190
 jharris@bondwater.com

8791 Snouffers School Rd - HVAC

Test	Hot Water Heat			
Conductivity (as mmhos)	3040 Record			
pH	9.7 8.5 - 10.5			
Molybdate (ppm as Mo)	650 50 min			

Opening Comment

Performed water treatment service.

Hot Water Heat

Online 

Chemical testing found a high level of Mo in the glycol system. All readings indicate good corrosion protection in the closed system. The filter on the closed loop was replaced during this visit.

Closing Comment

Please contact me with any questions regarding the treatment program.

Bond Water Technologies, Inc. recommends that you perform regular and/or daily analysis to control chemical levels and cycles of concentration within established limits. Test results reflect conditions during the point in time when the analysis was performed. Additional testing may be performed upon request. As operating conditions vary, test results will change over time. Notwithstanding anything to the contrary contained in the Agreement or otherwise, (i) Bond Water Technologies and its insurers are not liable for losses caused by the Customers wrongful acts or omissions, (ii) Bond's program does not cover and it makes no guarantees with respect to waterborne pathogens including Legionella or against health risks therefrom, and (iii) in no event shall either party be liable for any consequential or indirect damages.