

Additional Funding Request

MD013 – Blower prover switch	CSS #25204 WO# 12323	Submitted May 22, 2020		
Description of Repairs	No hot water in training building			
Original SC Investigative Diagnosis	\$300.00			
Diagnosis: Initial Work Order	Heater #1 had a fault for "no anode voltage," took the prover switch to fix Heater #2. S&S will need to order a new prover switch, install it then troubleshoot the original fault.			
Explanation of Additional Costs for Repairs	N/A			
Additional Material Cost to Perform Repairs	Materials: \$94.75			
	ITEM	QUANTITY	UNIT PRICE	TOTAL
	Blwr Prover Switch / S100111056	1	\$90.24	\$90.24
	Tax	1	\$4.51	\$4.51
	TOTAL		\$94.75	\$94.75
Additional Labor Cost to Perform Repairs	Labor: \$600.00 Plumber Labor Tech/6 hours/Rate \$100.00 per hour = \$600.00			
Total Cost of Repair	\$994.75			