

## Additional Funding Request

### WITH INVOICE

Submitted: 5/31/2022

<b>MD016 Water Line</b>	<b>CSS #847 WO#17790</b>								
Description of Repairs	When I arrived the guy who met me had tried to shut the water off but it was still leaking a little, used channel locks to shut the valve off completely. Capped the pipe off where it comes out of the ground in the garage, so it won't be turned on from the building accidentally. The intruder cut the water line out that ran from the ground to the other side of the garage from a hose bib; POC informed me they did not want a quote to replace piping due to the building not being in use. POC just wanted it shut off and capped. Work complete.								
Original SC Investigative Diagnosis	\$NA								
Diagnosis: Initial Work Order	Main water line Flooding in OMS Shop area - Possible theft of pipes								
Explanation of Additional Costs for Repairs	N/A								
Additional Material Cost to Perform Repairs	<p><b>Materials: \$23.86</b></p> <table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th style="text-align: left; padding: 2px;">ITEM</th> <th style="text-align: center; padding: 2px;">QUANTITY</th> <th style="text-align: center; padding: 2px;">UNIT PRICE</th> <th style="text-align: center; padding: 2px;">TOTAL</th> </tr> </thead> <tbody> <tr> <td style="text-align: left; padding: 2px;">Parts detailed on invoice</td> <td style="text-align: center; padding: 2px;">1</td> <td style="text-align: center; padding: 2px;">\$23.86</td> <td style="text-align: center; padding: 2px;">\$23.86</td> </tr> </tbody> </table>	ITEM	QUANTITY	UNIT PRICE	TOTAL	Parts detailed on invoice	1	\$23.86	\$23.86
ITEM	QUANTITY	UNIT PRICE	TOTAL						
Parts detailed on invoice	1	\$23.86	\$23.86						
Additional Labor Cost to Perform Repairs	<p><b>Labor: \$600.00</b></p> <p>4 hours each/Plumbing frate Overtime Rate \$150.00 per hour = \$600.00</p>								
<b>Total Cost of Repair</b>	<b>\$623.86</b>								