

CERTIFICATION OF WORK

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: Upper Marlboro MD 2016 Date of Visit: 7/8/19

Contractor Personnel on Site:

1. Patrick Donovan

2. _____

Work Performed:

Preventive Maintenance - Services Completed (Annual, Quarterly, Monthly, equipment identification, etc.)

1. 9051, 9542, 9514, 9543

Fences, Overhead doors, Circulating Pump, Flood lights

Service Calls – Service Call Number and Description

1. CSS# _____

2. CSS# _____

3. CSS# _____

CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: Patrick Donovan Date: 7/8/19

Signed: Patricia Jack

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: Jason Gavin AFOS Date: 7/8/19

Signed: Jason Gavin

E-Mail: _____

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
MANUAL/AUTOMATIC OVERHEAD DOORS

SITE AND BLDG #: Upper Milwaukee, WI **WO#** 9542 **ASSET #** 20114204

MECHANIC
SIGNATURE: John P. P. S.

DATE: 8/19

FINISH TIME: 4:10

ITEM	DESCRIPTION	NOTES	REMARKS
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered.		
2	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.		
1	Check with door operating personnel for any known deficiencies.		
2	Inspect general arrangement of door and mechanism, mountings, standards, wind locks, anchor bolts, counterbalances, weather stripping, door sweeps etc. Clean, tighten, and adjust repair as required.		
3	If applicable, operate with power from start to stop and at intermediate positions. Observe performance of various components, such as brake, limit switches, door operating speed, motor, gear box, etc. Clean and adjust as needed.		
4	Check operation of safety edges, stops, electric eye, treadle, or other operating devices. Clean and make required adjustments or repairs.		
5	Check manual operation. Note brake release, motor disengagement, functioning of hand pulls, chains sprockets, clutch etc		
6	If applicable, examine all wiring, motor, starter, push button, etc., blow out or vacuum if needed.		
7	If applicable, inspect gear box, change or add oil as required.		
8	Perform required lubrication. Remove old or excess lubricant.		
9	Clean unit and mechanism thoroughly. Touch up paint where required.		
10	Clean up and remove all debris.		

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: General Maintenance Worker

Additional Notes: