

Additional Funding Request

Submitted: 12/20/2018

MD016 – emergency light	CSS #16665 WO#6853
Description of Repairs	Emergency light on 2nd FL outside 13th LOD office. Not working properly, safety issue.
Original SC Investigative Diagnosis	Diagnoses Labor: \$250.00 1 HVAC Technician/2.5hours/ Rate \$100.00 per hour = \$250.00 S&S will return to install the new emergency light on the second floor.
Diagnosis: Initial Work Order	S&S was on site and diagnosed that emergency light on the second floor needs to be replaced.
Explanation of Additional Costs for Repairs	N/A
Additional Material Cost to Perform Repairs	Materials: \$30.79 Emergency Fixture/ 08008356650 = \$29.05 Tax: \$1.74
Additional Labor Cost to Perform Repairs	Labor: \$300.00 1 HVAC Technician/3hours/ Rate \$100.00 per hour = \$300.00
Total Cost of Repair	\$580.79