

Additional Funding Request

Submitted: 4/9/2019

MD016 – boiler damage	CSS #18544 WO #8451
Description of Repairs	Follow up of emergency service call of 2 foot of water in mechanical room.
Diagnosis: Initial Work Order	<p>S&S Mechanical is providing this quote to CMI to replace the parts for the water heater that have been damaged due to motor room leak.</p> <p>❖ S&S will provide and install new gas valve for water heater.</p> <p>❖ S&S will provide system check of water heater once parts are installed.</p>
Diagnostic Fee	Diagnostic Total: NA
Explanation of Additional Costs for Repairs	NA
Additional Labor Cost to Perform Repairs	<p>Labor: \$300.00</p> <p>1 HVAC Technician /3 hours/ Rate \$100.00 per hour = \$300.00</p>
Additional Material Cost to Perform Repairs	<p>Material: \$545.44</p> <p>Gas Valve/70-1551/\$462.00 Shipping: \$25.00 Tax: \$58.44</p>
Total Cost of Repair	\$845.44