


PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST **EXPANSION TANKS**

SITE AND BLDG #: MD019 B-1

**MECHANIC
SIGNATURE**



DATE: 08/24/22

LOCATION/RM #: **WO#** 18840 **ASSET #** 190918-194

START TIME 0900

FINISH TIME: 1630

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
SPECIAL INSTRUCTIONS				
1	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	/		
TO BE PERFORMED AT EACH INSPECTION SERVICE				
1	Examine exterior of tank including fittings and valves for leaks, signs of corrosion, and correct as needed.	/	/	
2	If applicable, Check sight glass, insure level is between 1/2 and 3/4 sight glass. Correct as needed.	/		
3	If applicable, check tank pressure via schrader valve. Correct as needed.	/		

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed discription of the deficiency.

To be performed by: General Maintenance Worker

Additional Notes: