

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
REACH-IN REFRIGERATORS/ FREEZERS

SITE AND BLDG #: MD019 B-1

MECHANIC
SIGNATURE:


DATE: 05/16/22

LOCATION/RM #: WO# 17216 ASSET # 1540, 1541

START TIME: 0900

FINISH TIME: 1630

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
SPECIAL INSTRUCTIONS				
1	De-energize, lock out, and tag electrical circuits.	✓		
2	If appliance is disposed, follow regulations concerning removal of refrigerants and disposal of the appliance.	✓		
TO BE PERFORMED AT EACH INSPECTION SERVICE				
1	Check with operating or area personnel for any deficiencies; verify cleaning program.	✓		
2	Verify indicator light on; check compartment temperature.	✓		
3	Examine evaporator for proper clearances/slope and air flow.	✓		
4	Examine handles, hinges and tightness of door closure.	✓		
5	Examine safety door release and fan shut down safety switch.	✓		
6	Inspect lighting for burnt out lamps. Replace if required.	✓		
7	Clean evaporator coil, evaporator drain pan, blowers, fans, motors, and drain piping as required; lubricate motor(s).	✓		
8	Clean condenser coil and condensing unit section.	✓		
9	Clean and inspect defrost evaporation trays/pans.	✓		
10	Check operation of thermostats; calibrated as required.	✓		
11	Check coil superheat and adjust to manufacturers recommendations.	✓		
12	Inspect and service all electric motors.	✓		
13	Check box floor for water or ice accumulation.	✓		
14	Clean up area and note any deficiencies.	✓		

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed discription of the deficiency.

To be performed by: General Maintenance Worker

Additional Notes: