

Thursday, May 27, 2021 9:07 AM EDT

Tidewater, INC
 MD-019
 12100 Greenspring Ave
 Owings Mills MD 21117-1610
 (410) 540-8700

Report Number: 365961-1
 Recorded By: Jon Miller
 (301) 580-9820
 jmiller@bondwater.com

MD-019 - Closed Loops

Test	Hot Loop	Chilled Glycol Loop		
Conductivity (as mmhos)	980 3500 max	2145 3500 max		
pH	8.3 8 - 10.5	8.5 8 - 10		
Molybdate (ppm as Mo)	250 50 - 200	80 50 - 200		

Opening Comment

Checked in and gained access to the boiler room this morning by Sargnt Schaffer.

Hot Water Loop

Online 

Performed all tests for hot water loop. All readings were within desired range, providing plenty of corrosion protection.

Chill Water Glycol Loop

Online 

Performed all tests for chilled glycol system. All readings were within desired range, providing optimal corrosion protection.

Closing Comment

I checked out of the boiler room with Sargent Schaffer.

Bond Water Technologies, Inc. recommends that you perform regular and/or daily analysis to control chemical levels and cycles of concentration within established limits. Test results reflect conditions during the point in time when the analysis was performed. Additional testing may be performed upon request. As operating conditions vary, test results will change over time. Notwithstanding anything to the contrary contained in the Agreement or otherwise, (i) Bond Water Technologies and its Insurers are not liable for losses caused by the Customer's wrongful acts or omissions, (ii) Bond's program does not cover and it makes no guarantees with respect to waterborne pathogens including Legionella or against health risks therefrom, and (iii) in no event shall either party be liable for any consequential or indirect damages.