

PREVENTIVE MAINTENANCE CERTIFICATION OF WORK

(To be completed by the Contractor and saved in the Contractor's CMMS)

FacID Building: *Riverdale MD020*

Date of Visit:

3/13/19

Contractor Personnel on Site:

1. *Patrick Donovan*

4.

8.

5.

6.

6.

Work Performed:

Preventive Maintenance - Services Completed (Annual, Quarterly, Monthly, equipment identification, etc.)

5. LIST WORK *7504, 7644, 7842, 7648, 7739*

6. *Lightning Rod, Grease Trap, Hot water Pumps, Baseboard Radiators, Electric Heaters, Mini Splits, overhead vehicle Exhaust System, Radiant Heaters, Gas heaters*

CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: *Patrick Donovan*

Date: *3/13/19*

Signed: *[Signature]*

To be signed by Facility Manager or Government Official

I certify that the above named individuals representing the Contractor arrived on site and to the best of my knowledge, completed the stated work listed:

Print Name Rank: *Clayton A. White, LTC* Date: *20190313*

Signed: *[Signature]*

E-Mail: *clayton.a.white.mil@mail.mil*

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
RADIANT BASEBOARDS/CONVECTORS (STEAM, HOT WATER, OR ELECTRIC)

SITE AND BLDG #: *Riverdale MPO20*

LOCATION/RM #: *Hall Stairs* **WO#** *2644* **ASSET #** *Scenes*

MECHANIC SIGNATURE: *J. S. S.* **DATE:** *3/13/19*

START TIME: *8:35* **FINISH TIME:** *11:00*

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ACTIONS (IF TASK COMPLETE IS CHECKED NO PROVIDE EXPLANATION)
		YES	NO	
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered to.	✓		
2	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	✓		
3	Check radiator valve for free turning and seating. Check packing.	✓		
4	Remove covers or wall panels. Note: Extreme care must be taken when removing marble or granite wall panels. These panels are extremely heavy and very fragile.	✓		
5	Check housing, braces, supports, hangers, and hardware for signs of deterioration or damage.	✓		
6	Check temperature or flow controls, shutoff valves, vents and traps for proper operation.	✓		
7	If radiator has automatic temperature regulating valve, remove valve cover and remove dirt by vacuuming.	✓		
8	For hot water radiators, check air bleed valve.	✓		
9	Wire brush and treat with rust inhibitor all rusted areas.	✓		
10	Check coils, piping, and fin material for damage, leaks or looseness. Straighten finned material as necessary.	✓		
	Clean and replace covers or wall panels and caulk wall panels as required. Clean work area.	✓		<i>close all good</i>

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: General Maintenance Worker

Inspected all. all in good shape

Additional Notes:

Asset # 2074 ✓

2075 ✓

2076 ✓

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST RECIRCULATING AIR BOOSTER PUMPS

CIRCULATING AND BOOSTER PUMPS

SITE AND RE DGE #: *71-1000*

MECHANIC SIGNATURE.

DATE: 3/3/16

LOCATION/RM #: Mechanical Room WO# 7644 ASSET # See Notes

START TIME: 9:30

FINISH TIME: 11:00

POINT	THE STANDARD SECTION	TASK COMPLIANCE		NOTES/ ACTIONS (IF TASK NOT COMPLETED NO PROVIDED EXPLANATION)
		YES	NO	
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered to.	✓		
2	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	✓		
3	It is generally not a good idea to tamper with pumps using mechanical seals if they are otherwise performing properly. Since mechanical seals can cost as much as the pump, it is usually not cost effective to risk damaging the seal by performing an annual internal inspection of the pump.	✓		
NOTES/ ACTIONS (IF TASK NOT COMPLETED NO PROVIDED EXPLANATION)				
NOTIFICATION OF EACH INSPECTION SERVICE				
1	Lubricate pump and motor bearings as per manufacturer's specifications.	✓		
2	Bearings require lubrication atleast annually.	✓		
3	Inspect couplings and check for any pump seal leaks.	done all good		
4	Check motor mounts and vibration pads	✓		
5	Tighten all pump flanges.	✓		
6	Visually check pump alignment and coupling	done		
	Inspect electrical connections	done		

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: General Maintenance Worker

Additional Notes:

Asset # 1655 ✓

#1666

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
GREASE TRAP

SITE AND BLDG #: Riverdale MD202

MECHANIC SIGNATURE: John S.

DATE: 3/11/19

LOCATION/RM #: Outside Kitchen **WO#** 7644 **ASSET #** 1551

START TIME: 10:15

FINISH TIME: 10:35

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
2	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
3	Insure proper grease disposal.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
1	Do not use enzymes, acids, caustics, solvents or emulsifying products when cleaning or maintaining the grease traps.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<u>done</u>
2	Remove lid. If the trap is equipped with removable baffles, remove them.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<u>done</u>
3	Make sure the flow restrictor on the inflow pipe is present.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<u>done</u>
4	If damages, missing parts, or cleaning is required, report them as needed to ensure proper working operation.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<u>done</u>
5	Replace lid and baffles.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<u>done</u>
6	Return (or fill) water to grease trap	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<u>done</u>
7	Record grease trap maintenance activities on your log or request a receipt from your grease hauler. Keep records for 3 years.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<u>done</u>

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: General Maintenance Technician

Additional Notes:

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
 UNIT HEATER, ELECTRIC

MECHANIC
 SIGNATURE: *L. Shaefer*

SITE AND BLDG #: *Riverdale MDO20*

DATE: *3/11/19*

LOCATION/RM #: *Rm 124* WO# *7644* ASSET # *2077*

START TIME: *9:15* FINISH TIME: *9:30*

ITEM	1	2	3	4	5	6	7	8
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered to.							
2	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.							
3	Check heater coils and associated piping for leaks or corrosion.	✓						
4	Clean heating coil. Brush vacuum where accessible.	✓						
5	Inspect wiring and electrical controls for loose connections, charred, frayed or broken insulation, evidence of short circuiting, wrong size fuses, circuit breakers, or switches, and other electrical deficiencies. Tighten any loose connections.							
6	Inspect fan for bent blades, unbalance, excessive noise and vibration.	✓						
7	Check motor and fan shaft bearings for noise, vibration, overheating, lubricate bearings.	✓						
8	Verify proper control by modulating the thermostat through complete cycle.	✓						
	Inspect unit for proper operation.	✓						
	Inspect unit for overall condition and recommend for replacement or other needed repairs.	✓						

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: HVAC Technician

Additional Notes: