

## Additional Funding Request

Submitted: 6.23.2020

<b>MD021</b> – chiller evaporator sensor	<b>CSS #25182 WO# 12443</b>																
Description of Repairs	12320/12443 -Chiller Evaporator sensor is reading failed in the system. Replacement is required.																
Original SC Investigative Diagnosis	<b>NA</b>																
Diagnosis: Initial Work Order	Chiller evaporator sensor is reading failed in the system. S&S proposes to remove and replace the faulty evaporator sensor. S&S will then complete a system check to ensure everything is running properly.																
Explanation of Additional Costs for Repairs	N/A																
Additional Material Cost to Perform Repairs	<p><b>Materials: \$117.17</b></p> <table border="1"> <thead> <tr> <th>ITEM</th> <th>QUANTITY</th> <th>UNIT PRICE</th> <th>TOTAL</th> </tr> </thead> <tbody> <tr> <td>Evaporator Sensor/ 154174</td> <td>1</td> <td>\$75.30</td> <td>\$75.30</td> </tr> <tr> <td>Tax</td> <td>1</td> <td>\$16.87</td> <td>\$16.87</td> </tr> <tr> <td>Shipping</td> <td>1</td> <td>\$25.00</td> <td>\$25.00</td> </tr> </tbody> </table>	ITEM	QUANTITY	UNIT PRICE	TOTAL	Evaporator Sensor/ 154174	1	\$75.30	\$75.30	Tax	1	\$16.87	\$16.87	Shipping	1	\$25.00	\$25.00
ITEM	QUANTITY	UNIT PRICE	TOTAL														
Evaporator Sensor/ 154174	1	\$75.30	\$75.30														
Tax	1	\$16.87	\$16.87														
Shipping	1	\$25.00	\$25.00														
Additional Labor Cost to Perform Repairs	<p><b>Labor: \$800.00</b> HVAC Labor Tech/8 hours/Rate \$100.00 per hour = \$800.00</p>																
<b>Total Cost of Repair</b>	<b>\$917.17</b>																